C-72

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

आज़ादी का अमृत महोत्सव

No. F6/DFS/MS/EH/NDZ/2026/414 Dated: -30/04/2026

To,

The Commissioner,
Municipal Corporation of Delhi,
Civic Centre, Minto Road,
New Delhi – 110001.

Sub: Regarding renewal of FSC in r/o M/s Cocorico Cafe and Bar, 2206, Ground Floor, Raj Guru Road, Paharganj, New Delhi - 110055.

Sir,

Please refer to online application No. 2026040304217 dated 03/04/2026, on the subject cited above. In this connection, it is to inform you that the said restaurant was inspected by the officers concerned of this department on **09/04/2026** in the presence of **Sh. Amit Kumar, Manager** and following shortcomings were observed: -

1. Smoke Management System provided but found non-functional.
2. Overhead Water Storage provided 10,000 Ltrs. against required capacity of 20,000 Ltrs.

Keeping in view of the above **shortcomings**, the application for renewal of Fire Safety Certificate cannot be considered at this stage and stands **rejected**. Further, the occupancy of the building premises in the absence of requisite fire safety measures shall be at the risk and liability of the owner/occupier.

Yours faithfully,

30/4/26

(Dr. S. K. Tomar)
Chief Fire Officer
Delhi Fire Service
O/C BP

Copy to: -

1. The Chairman, NDMC, Palika Kendra, Parliament Street, New Delhi - 110001
2. The Manager, M/s Cocorico Cafe and Bar, 2206, Ground Floor, Raj Guru Road, Paharganj, New Delhi - 110055.