GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

आज़ादी का अमृत महोत्सव

No. F6/DFS/MS/SZ/2026/ 68 Dated:- 22/01/2026

To,

The Commissioner,
Municipal Corporation of Delhi,
Civic Centre, Minto Road,
New Delhi -110002.

Sub.:- Regarding issuance of Fire Safety Certificate in r/o M/s Connaught Plaza Restaurant Pvt. Ltd. McDonalds Family Restaurant, located at Plot No. 34, Block B-1, Ashok Vihar, Phase-II, Delhi-110052.

Sir,

This has reference to online application no. 2025121915912 dated 22/12/2025 on the subject cited above. In this connection, it is to inform you that the above said building was re-inspected by the officer concerned of this department on 14/01/2026 in the presence of Mr. Anurag Shrivastav to check the compliance of shortcomings issued by this department vide letter no. F6/DFS/MS/EH/WZ/2025/452 dated 27/11/2025.

During inspection, it have been observed that the shortcomings issued by this department vide above said letter has not been rectified yet.

In view of the above, the application for issuance of Fire Safety Certificate cannot be considered at this stage & rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing Authority/statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

21/01/26

S.K. Dua
Dy. Chief Fire Officer (WZ)
Delhi Fire Service

21/01/26

Copy to:-

1. The Authorized Signatory, M/s. Connaught Plaza Restaurant Pvt. Ltd. McDonalds Family Restaurant, located at Plot no. 34, Block B-1, Ashok Vihar, Phase-II, Delhi – 110052.

C-7

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No.F.6/DFS/MS/EH/WZ/2025/ 452 Dated: 27/11/2025

To,

Sh. Rajeev Goel,
M/s Connaught Plaza Restaurant Pvt. Ltd. McDonalds Family Restaurant
First floor, Plot no. 34, Block B-1, Ashok Vihar, Phase-II,
Delhi -110052

Subject:-Regarding issuance of Fire Safety Certificate in r/o M/s Connaught Plaza Restaurant Pvt. Ltd. McDonalds Family Restaurant located at First floor, Plot no. 34, Block B-1, Ashok Vihar, Phase-II, Delhi -110052.

Sir,

This has reference to MCD application ID No. **2025110414601** dated 05/11/2025 on the subject cited above. In this connection, it is to inform you that the premises was inspected by the officer concerned of this department on dated 15/11/2025 of the above-mentioned Restaurant from fire safety point of view in presence of Mrs. Jyoti Arora (Manager). The premises is comprised of Basement, stilt, Ground plus two upper floors but restaurant is running ground floor (above stilt) only. The following shortcoming was observed during the time of inspection.

1. The corridor width of 0.90 meter to 1.18 meter is provided against the requirement width of 1.50 meter.

In view of above shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire Safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

24/11/25

(S. K. DUA)
DY. CHIEF FIRE OFFICER
DELHI FIRE SERVICE

MCD ID NO. 2025110414601

O/C R.