282

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

आजादी का अमृत महोत्सव

No. F6/DFS/MS/GH/NDZ/2026/ 154 Dated: -20/02/2026

To,

The Commissioner,
Municipal Corporation of Delhi,
Civic Centre, Minto Road,
New Delhi

Sub: Regarding renewal of Fire Safety Certificate in r/o M/s Coral Plaza, 2039/7, Gali No.-7, Chuna Mandi, Paharganj, New Delhi - 110055.

Sir,

Please refer your online application ID No. 2026013001072 dated 30/01/2026 on the subject cited above. In this connection, it is to inform you that the said building was inspected by the officer concerned of this department on 07/02/2026 in the presence of Sh. Arun Chopra, Owner and following shortcomings were observed: -

1. Width of corridor was 1.17 mtr. against required width of 1.50 mtr.
2. Automatic operation of Fire pump found removed.

Keeping in view of the above **shortcomings**, the application for renewal of Fire Safety Certificate cannot be considered at this stage and stands **rejected**. Further, the occupancy of the building premises in the absence of requisite fire safety measures shall be at the risk and liability of the owner/occupier.

Yours Faithfully,

19/2/26

(Dr. S. K. Tomar)
Dy. Chief Fire Officer
Delhi Fire Service

O/C BP

Copy to: -

1. The Manager, M/s Coral Plaza, 2039/7, Gali No.-7, Chuna Mandi, Paharganj, New Delhi - 110055.