GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No. F6/DFS/MS/BP/2025/467 Dated: 22/09/2025

To,

The Executive Engineer (Bldg.) HQ
Municipal Corporation of Delhi,
9th floor, Civic Centre, Minto Road
New Delhi 110002

Sub: - Examination of building plans from fire safety point of view in r/o Construction of Industrial Building at Plot No. D-93 situated at Okhla Industrial Area Phase-I, New Delhi.

Sir,

Please refer your request ID. No. 10121013 dated 11/09/2025 of online building plans, on the subject cited above. In this connection, this is to inform you that the building plans have been scrutinized by this department from fire and life safety point of view and following shortcomings are observed: -

1. Clear cut occupancy is not marked on the building plans as per clause 1.4.75 of UBBL – 2016.

In view of the above, the building plans are hereby rejected.

Yours faithfully

19/9/2025

(Virendra Singh)
Chief Fire Officer
Delhi Fire Service