**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**
**HEADQUATERS: DELHI FIRE SERVICE: NEW DELHI–110001**

No. F.6/DFS/MS/CGHS/2025/SZ/ 501 Dated: 22/10/2025

To

Sh. Balraj Singh Bisht (Secretary),
Daffodils CGHS Limited,
Plot No. 36, Sector–06,
Dwarka, New Delhi–110075

**Sub: Regarding issuance of Fire Safety Certificate in r/o Daffodils CGHS Ltd located at Plot No. 36, Sector–06, Dwarka, New Delhi-110075.**

Sir,

This has reference to your letter No. Daff/Fire Safety/2025/02 dated 08/09/2025 received in this department vide outdoor diary No. 5697 dated 08/09/2025, on the subject cited above. In this connection, it is to inform you that the premise was inspected by the officer concerned of this department on 25/09/2025 in your presence from fire safety point of view. During course of inspection, the shortcomings observed in the existing building and the same are as below: -

1. CGHS Board installed at entry gate is below the required height of 4.5 meter and obstructs the entry to fire-fighting vehicles.
2. First aid hose-reel system provided but non-functional.
3. Hose-boxes found removed at some places.
4. Terrace level fire pumps provided but non-functional.
5. Lift signage's and exit signage's found removed at some locations.

In view of the above, application for issuance of fire safety certificate cannot be considered at this stage. You are advised to rectify and submit compliance of above shortcomings for further action in the matter, till than the occupancy of the residential buildings shall be at the risk & liability of the management committee.

Yours faithfully,

24/9/25

**(A.K. Malik)**
Dy. Chief Fire Officer (SZ)
Delhi Fire Service

Copy to: -

1. The Dy. Director (L&I), Building Section, Delhi Development Authority, Vikas Sadan, INA, New Delhi–110023