GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

आज़ादी का अमृत महोत्सव

No. F6/DFS/MS/EH/WZ/2026/ 521 Dated: 03/06/2026

FIRE SAFETY CERTIFICATE

Certified that the M/s Daryaganj (A unit of Saaj Foods and Hospitality Pvt. Ltd.) located at Unit No.11, Second floor of Pacific Mall in building comprised of Two Basement, Ground plus Four Upper Floors & Projection room located at Khayala, Subhash Nagar Metro Station, New Delhi owned/occupied by Saaj Foods & Hospitality Pvt. Ltd., was granted fire safety certificate by this department vide letter no. F6/DFS/MS/EH/WZ/2023/132 dated 26/04/2023. Now, The premises was re-inspected by the officer concerned of this department on 23/05/2026 in the presence of Mr. Dalbir Singh (Manager) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy class –'D' Assembly (Restaurant running at second floor only) for with effect from 03/06/2026 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subjected to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on .03/06/2026. at New Delhi by.

Yours faithfully,

02/06/26

(S. K. Dua)
Chief Fire Officer
Delhi Fire Service

Copy to:

1. The Commissioner, MCD, Civic Centre, New Delhi: to kindly ensure the occupancy as detailed above and deviation in construction if any: Online MCD Portal ID-2026051406837 dated 14/05/2026.
2. The Owner/Occupier, M/s Daryaganj (A unit of Saaj Foods and Hospitality Pvt. Ltd.), Unit No.11, Second floor, Pacific Mall, Khayala, Suhash Nagar Metro Station, Delhi.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management/occupier.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.
9. This FSC is valid for the restaurant located at 2nd floor only.

INSPECTION REPORT

1	Name & Address of the building	M/s Daryaganj (A unit of Saaj Foods and Hospitality Pvt. Ltd.) located at unit No.11, Second floor, Pacific Mall, Khayala, Suhash Nagar Metro Station, Delhi.
2	Building is comprised of	Two Basement + Ground + 04 Upper floors (Restaurant running at Second floor in Pacific Mall)
3	Type of occupancy	Eating House /Assembly Occupancy
4	Type of case	Renewal Case
5	Details of previous FSC	F6/DFS/MS/EH/WZ/2023/132 dated 26/04/2023
6	Fire safety direction letter no.	Nil
7	Date of inspection	23/05/2026
8	Name of the inspecting officers	Mohd. Firoz Khan, ADO/MN
9	Name of the designation of officer From the building side	Mr. Dalbir Singh (Manager)
10	Year of construction	2011
11	Applicant's letter no.	MCD Application No. 2026051406837 dated 14/05/2026

The said restaurant is Running at second floor in Pacific Mall in a building comprised of two basement, ground & four upper floors & projection room was issued FSC vide letter no. F6/DFS/MS/WZ/Mall/2023/349 dated 21/07/2023.

S. No		Minimum standard of Fire Prevention and Fire Safety U/R 33	BBL / NBC Requirements	Provide at site	Remarks MR/NMR
1		**Access to Building**			
	A	Road width	12 m	Provided(60)	MR
	B	Gate width	06 m	Provided	MR
	C	Width of internal roads	06 m	Provided	MR
2		**Number, Width, Type & Arrangement of Exits**			
	A	No. of staircase:			
		a) Upper floor	2 nos.	11 nos. (Provided by mall)	MR
		b) Basements	NA	NA	Restaurant running at SF
	B	Width of the staircase:			
		a) Upper floors	1.5 mtr each	Provided	MR
		b) Basements	NA	NA	Restaurant running at SF
	C	Protection of Exits			
		a) Fire check door	NA	Provided by mall	NA
		b) Pressurization	NA	Provided by mall	NA
	D	No. of continuous staircase to terrace:	Required	Provided by mall	MR
	E	Width of the corridor	NA	NA	NA
	F	Door size	2.0 m, 1.5 m	2.6 m X 02, 1.5 m X 01	MR
3		**Compartmentation:**			
	A	Fire check doors	NA	Provided by mall	NA
	B	Sealing of horizontal & vertical opening	NA	Provided by mall	NA
	C	Fire rating of shaft doors	NA	Provided by mall	NA
	D	Water curtain	NA	Provided by mall	NA
	E	Fire dampers	NA	Provided by mall	NA
4		**Smoke management System:**			
	A	Basements	NA	NA	Restaurant running at SF
	B	Upper floors	Required	Provided	MR
5		**Fire Extinguishers**			
	A	Total numbers	06 nos.	Provided	MR
	B	Types	ABC & CO2	Provided	MR
	C	ISI marking	ISI marked	Provided	MR

6	**First Aid Hose Reel**				
	A	Total no. at each floor	01 no.	Provided by mall restaurant	MR
	B	Length of hose reel	30 m	Provided	MR
	C	Nozzle diameter	5 mm	Provided	MR
7	**Automatic Fire Detection and Alarm System**				
	A	Type of detectors	Smoke & Heat	Provided & connected with the Mall	MR
	B	Location of main Panel	Required at G.F.	Provided	MR
	C	Location of repeater panel	Required	Provided	MR
	D	Alternate power source	Required	Provided by Mall	MR
	E	Hooter's location	Required	Provided in restaurant & Mall	MR
8	MOEFA		Required	Provided in restaurant & Mall	MR
9	Public Address System		Required	Provided by Mall	MR
10	**Automatic Sprinkler System**				
	A	Basement	NA	Provided by Mall	NA
	B	Upper floor	Required	Provided by Mall	MR
	C	Sprinklers above false ceiling	Required	Provided by Mall	MR
11	**Internal Hydrants**		**Common with the Mall**		
	A	Size of the riser/down comer	150 mm	Provided near restaurant & Mall	MR
	B	No. of hydrants per floor	01	Provided	MR
	C	Hose box	01	Provided	MR
12	**Yard Hydrants**				
	A	Total no. of hydrants	NA	NA	NA
	B	Hose box	NA	NA	NA
13	**Pumping arrangements**		**Common with the Mall**		
	A	Ground Level			
		a) Discharge of main pump	2850 LPM	Provided by Mall	MR
		b) Head of Main Pump	60 m	Provided by Mall	MR
		c) Number of Main Pump	02	Provided by Mall	MR
		d) Jockey Pump out put	180 LPM	Provided by Mall	MR
		e) Jockey Pump Head	60 m	Provided by Mall	MR
		f) Standby Pump out put	2850 LPM	Provided by Mall	MR
		g) Standby Pump Head	60 m	Provided by Mall	MR
		h) Auto Starting/ Manual stopping	Required	Provided by Mall	MR
		i)Pump House access	Required	Provided by Mall	MR
	B	Terrace Level			
		Discharge of Pump	450 LPM	Provided by Mall	MR
		Head of terrace pump	30 m	Provided by Mall	MR
		Power supply	Required	Provided by Mall	MR
		Auto starting of pump	Required	Provided by Mall	MR
14	**Captive Water Storage for Fire Fighting.**		**Common with the Mall**		
	A	Underground tank capacity	2,00,000 litres	Provided by Mall	MR
	B	Draw off connection	Required	Provided by Mall	MR
	C	Fire Service Inlet	Required	Provided by Mall	MR
	E	Access to tank	Required	Provided by Mall	MR
	D	Overhead tank capacity	30,000 litres	Provided by Mall	MR
15	**Exit Signage**		Required	Provided	MR
16	**Provision of lift**				
	A	Pressurization of lift shaft	Required	Provided by mall	MR
	B	Pressurization of lift lobby	Required	Provided by mall	MR
	C	Communication in lift car	Required	Provided by mall	MR
	D	Fireman switch	Required	Provided by mall	MR
	E	Lift signage	Required	Provided by mall	MR
17	**Standby Power Supply**		Required	Provided	MR

18	**Refuge Area**				
	A	location	N/A	N/A	N/A
	B	Total area	N/A	N/A	N/A
19	**Fire Control Room**				
	A	Fire Detection System panel	Required	Provided by mall	MR
	B	Flow switch panel	Required	Provided by mall	MR
	C	P A system panel	Required	Provided by mall	MR
	D	Battery backup	Required	Provided by mall	MR
	E	Building floor plan	Required	Provided by mall	MR
20	**Special Fire Protection for special risk if any**				
	A	Special Fire Protection system for Protection of Special Risk, if any:	Required	Fire protectikon system provided in Kitchen hood	MR

The fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection. The shortcoming issued by this department vide letter no. F6/DFS/MS/EH/WZ/2026/459 dated 13/05/2026 has been rectified.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the FSC issued vide letter no. F6/DFS/MS/EH/WZ/2023/132 dated 26/04/2023 is recommended for renewal of FSC under rule 37 of the Delhi Fire Service rules 2010.

Accordingly, DFA is prepared and placed opposite for perusal and approval please.

Note: - Last disposal date of the case is 12.06.2026.

25/5/2026

Signature of the Inspecting Officer
Name: Mohd. Firoz Khan
Designation: ADO/Moti Nagar

D.O/WD

25/5

CFO/WZ

26/05/26

Pr. Director

CFO to

27/05/26

CFO (WZ)

F.F. please.

29/05/26

ADO (MN)

Sir FF is put up for your kind perusal and signature please.

01/06/2026

CFO (WZ)

02/06/26

F.F. wing

Uploaded 03/6/26