GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

आज़ादी का अमृत महोत्सव

No. F.6/DFS/MS/EH/NDZ/2026/578 Dated: 19/06/2026

To

The Commissioner,
MCD, 9th Floor, Dr. SPM Civic Centre,
Minto Road, New Delhi–110002.

Ref: Online application no. 2026060107799.

Sub: Regarding issuance of Fire Safety Certificate in r/o M/s Dasaprakash (A Unit of Das Kitchen) located at Ground and First floor, shop no. 107, 108 and 109, Meharchand Market, Lodhi Colony, New Delhi.

Sir,

In context to the subject and reference mentioned above it is informed that the said Eating House was visited by the officer concerned of this Department on 10.06.2026 and it was noticed that the shortcomings issued vide letter no. F.6/DFS/MS/EH/2026/SZ/499 dated 21.05.2026 have not been rectified till date.

Hence this case is rejected. In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

18/6/26
(A.K. Malik)
Chief Fire Officer
Delhi Fire Service

o/c 16/6/26

Copy to: -

1. The Owner/Occupier/Manager, M/s Dasaprakash (A Unit of Das Kitchen) located at Ground and First floor, shop no. 107, 108 and 109, Meharchand Market, Lodhi Colony, New Delhi.

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI C16
HEADQUATERS: DELHI FIRE SERVICE: NEW DELHI–110001

No. F.6/DFS/MS/EH/2026/SZ/499 ated: 21/05/2026

To

The Commissioner,
Municipal Corporation of Delhi,
9th Floor, Dr. SPM Civic Centre,
Minto Road, New Delhi–110002

Sub: **Regarding issuance of Fire Safety Certificate in r/o M/s Dasaprakash (A unit of Das Kitchens) situated at Shop No. 107-108-109, GF & FF, Mehar Chand Market, Lodhi Colony, New Delhi–110003.**

Sir,

This has reference to the online portal Id. No. **2026042505774** dated 25/04/2026. In this connection, it is to inform you that the said premise was visited by the officer concerned of this department on dated 12.05.2026 in the presence of Mr. Ajay (Operation Manager) to verify the availability and operability of fire and life safety provisions. During course of inspection, the shortcomings observed are as below.

1. Fire check door is not provided at kitchen exit door.
2. First-aid hose reel and hydrant system found provided but non-functional.
3. MOEFA found provided but non-functional.
4. The terrace level fire pump found provided but non-functional.
5. The required exit signage not provided.
6. The required standby Power supply not provided.

In view of the above, application for issuance of fire safety certificate cannot be considered and hence, **rejected**. The occupancy of the premises in the absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully,

20/5/26

(A.K. Malik)
Chief Fire Officer
Delhi Fire Service

Copy to: -

1. Sh. Sandeep Singh. M/s Dasaprakash (A unit of Das Kitchens), Shop No. 107-108-109, GF & FF, Mehar Chand Market, Lodhi Colony, New Delhi–110003