C/40

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DLEHI - 110 001

No. F.6/DFS/MS/WZ/EH/2026/ 190 Dated: 03/03/2026

To,

Mr. Anand Ekambaram,
House No.E-401, Pearls Gateway Tower, Sector-44, Noida
Delhi-110041.

Sub: Renewal of FSC in r/o M/s Dasaprakash A unit of DAS Kitchens located at Plot No.35, block-B1, Upper ground floor, Ashok Vihar, Phase-II, Delhi-110052.

Sir,

This is refer to online application no. 2026020301202 dated 03.02.2026, received in this department on the subject cited above. The premise was inspected by the concern nominated authority of this department on 18.02.2026, in presence of Mr. Ajay Rawat (Area Manager) to ascertain the availability and operability of the fire prevention and fire safety measures. Your request for renewal of FSC is rejected under sub rule (3) of Rule 37 of DFS Rules-2010 due to following reason:

1. Manually operated electric fire alarm found provided but not functional.
2. Pumps are isolated due to sprinkle head damaged.
3. 15000ltrs Over Head water captive tank provided against the required capacity of 20,000 ltrs

In this regard as stipulated in sub Rule 37 of DFS Rules, 2010 you may apply with a fresh application for renewal of fire safety certificate under sub-rule (2) on Form "J" /MCD Portal with compliance of above shortcomings. The web links for DFS Act-2007/ Rules 2010 & Form "J" are as under:
http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms

Yours faithfully

02/03/26

(S. K. Dua)
Dy. Chief Fire Officer (WZ)
Delhi Fire Service

Copy To:-

1. MCD Portal Id- 2026020301202 dated 03.02.2026.