GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001

No. F6/DFS/MS/SZ/2026/726 **Dated:** 28/07/2026

To,

The Assistant Engineer (E),
PWD EMSD- II, South- West,
Najafgarh, New Delhi- 43.

Sub: - Regarding renewal of "FSC" from fire safety point of view in r/o Deen Dayal Uppadhayay Collage Buildings at Sector- 03, Dwarka, New Delhi.

Sir,

Please refer to your letter No. 4(33)/DDU/AE(E)/PWD S.D.-II/South-West/2026-27/89 dated 05.06.2026, on the subject cited above. In this connection, it is to inform you that officer concerned of this department visited the collage building on dated 10.07.2026 to verify the fire safety arrangements in accordance with the rules. At the time of inspection Sh. Sunil (Caretaker) was present the following shortcomings were observed: -

1. Hose reels provided as per requirement but found not functional.
2. MOEFA & PA System provided but found not functional.
3. Automatic sprinkler system provided in basement but found not functional.
4. Internal and Yard hydrant provided but found not functional.
5. Fire Pumps provided as per requirement but found not functional.
6. Exit signage's are found removed at some places.

In view of the above, renewal of 'Fire Safety Certificate' cannot be granted at this stage. You are requested to rectify the above-mentioned shortcomings under intimation to this department for taking further necessary action in this matter and running a educational building in absence of requisite fire safety arrangements shall be at the risk & liability of the collage management.

Yours faithfully

27/07/26

(S.K. Dua)
Chief Fire Officer
West Zone

Copy to: -

1. Director (Higher Education), Govt. of NCT of Delhi, 5 Sham Nath Marg, Delhi.
2. The Principal, DDU Collage Buildings at Sec. 03, Dwarka, New Delhi- 110077.