GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI – 110001

NO. F6/DFS/MS/SZ/2026/ 389 **DATED:** 03/09/**2026**

To,

The Assistant Commissioner of Police,
Delhi Police Academy
Dwarka Sector 9 New Delhi

Subject: - Renewal of Fire Safety Certificate in r/o Delhi Armed Police Line, Residential Quarters Located at Sector -9 Dwarka New Delhi-110075.

Sir,

Please refer to your letter no 302/Estate Br./DPA/Dwarka, New Delhi dated-27/07/2026 on the subject cited above. In this connection it is to inform to you that the above said residential building has been inspected by the officer concerned of this department on 12/08/2026 in the presence of Mr. Kuldeep (SI) for fire safety point of view.

During the course of inspection followings shortcoming have been observed:-

1. Six meter wide internal road around the building found blocked/encroached.
2. Fire check door found damage at few places
3. Hose Reels, yard & internal Hydrants system found nonfunctional.
4. Hoses / Nozzles were found missing at some floors.
5. MOEFA found nonfunctional.
6. PA system found nonfunctional.
7. Pump at ground &terrace level found nonfunctional.
8. Exit Sign's found removed at few places.
9. Lift Sign's found removed at few places
8. Overhead tank found empty.
9. Communication in lift Car found nonfunctional.
10. Fireman's Grounding Switch found nonfunctional

You are requested to comply the abovementioned shortcomings under intimation to this department.

In view of the above shortcomings Fire Safety Certificate cannot be considered at this stage

Yours faithfully,

2/9/26

(A.K. Malik)
Chief Fire Officer
Delhi Fire Service

Copy to:- The Joint Director, DDA, Vikas Sadan, INA, New Delhi.