GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

आज़ादी का अमृत महोत्सव

No. F6/DFS/MS/Storage/ECN/2026/472 Dated: 06 /11 /2026

To,

Authorized Signatory,
Delhi Cargo Service Center Pvt. Ltd.,
Cargo Terminal 2, Gate No. 6,
Air Cargo Complex, IGI Airport,
New Delhi – 110037.

Sub: Application for renewal of Fire Safety Certificate in r/o of Delhi Cargo Service Center Pvt. Ltd, Cargo Terminal – 2, Gate No. 6, IGI Airport, New Delhi - 110037.

Sir,

Please refer your online application No: 52026061203649 dated 24/06/2026, on the subject cited above. In this connection, it is to inform you that the said building was inspected by the officers concerned of this department on 25/09/2026 in the presence of Sh. Deepak Singh Karki, Sr. Manager and following shortcomings were observed: -

1. All around 06 mtr. wide motorable road with 09 mtr. turning radius for fire tender movement found encroached.
2. Fire Check Doors found removed at some places.
3. Smoke Management System provided but found non-functional.
4. Automatic Detection System found removed at some places.
5. Automatic Sprinkler System found removed at some places.
6. Total flooding system found removed in HT & LT Panels.

In view of the above shortcomings, the application for renewal of fire safety certificate cannot be considered at this stage & stands **rejected**. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(M. K. Chattopadhyay)
Dy. Chief Fire Officer
Delhi Fire Service
OIC BP

Copy To: -

1. General Manager (Fire), New Udaan Bhawan, Near T-3, IGI Airport, New Delhi – 110037.