GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

आज़ादी का अमृत महोत्सव

No. F6/DFS/MS/School/SZ/2026/909 Dated: 08/10/2026

To

The principal,
M/s Delhi International Happy School,
6288, Mathura Road, Bhogal,
New Delhi-14.

Sub:- Regarding issuance of Fire Safety Certificate in respect of M/s Delhi International Happy School located at 6288, Mathura Road, Bhogal, New Delhi-14.

Sir,

With reference to the letter bearing outdoor diary no. 5064 dated 12/08/2026 on the subject cited above, it is informed that the school building was inspected by officer concerned of this department on 09/09/2026 in the presence of Mr. S.S. Jain (Principal) and following shortcomings were observed during the inspection.

1. The width of alternate staircase is not meeting the requirement i.e. 1.50 meters at upper floors.
2. The width of the staircases to the basement is not meeting the requirement of 1.50 meters (each staircase).

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the school management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

7/10/26

(A.K. Malik)
Chief Fire Officer
Delhi Fire Service

05/10/26

Copy to:-.

1. The Dy. Director of Education, GNCT of New Delhi DISST. South Block-C, Defence Colony, New Delhi-24.