GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 11000

No. F6/DFS/MS/SZ/2025/459 Dated:- 01/12/2025

To,

The Commissioner,
Municipal Corporation of Delhi,
Civic Centre, Minto Road,
New Delhi -110002.

Sub.:- Regarding renewal of Fire Safety Certificate in r/o M/s Delhi Maharashtriya Samaj Buidling Trust Regd., located at 10085, Brihan Maharashtra Bhawan, Multani Dhanda, Opp., Pahar Ganj, Delhi-110055.

Sir,

This has reference to online application no. 2025103114508 dated 31/10/2025 on the subject cited above. In this connection, it is to inform you that the above said building was inspected by the officer concerned of this department on dated 19/11/2025 in the presence of Sh. Viny Moghe (Manager). During inspection observed that the above said building is comprised of basement + ground + 03 upper floors. However, the following shortcomings were observed:-

1. Smoke Manager System found non-functional.
2. First-aid hose reel found non-functional.
3. Automatic fire detector system found non-functional.
4. MOEFA found non-functional.
5. Public address system found non-functional.
6. Pump found non-functional.
7. Overhead water storage tank found empty.

In view of the above shortcomings, the application for renewal of Fire Safety Certificate cannot be considered at this stage & rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing Authority/statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

01/12/2025

(D.B. Mukerjee)
Dy. Chief Fire Officer

27/11/25

Copy to:-

1. The Authorized Signatory, M/s Delhi Maharashtriya Samaj Buidling Trust Regd., located at 10085, Brihan Maharashtra Bhawan, Multani Dhanda, Opp., Pahar Ganj, Delhi-110055.