C198

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

आज़ादी का अमृत महोत्सव

No. F.6/DFS /MS/BP/2026/ 575 Dated: 18 /06 /2026

To,

The Executive Engineer (Bldg.) HQ,
Municipal Corporation of Delhi,
Dr. S.P.M Civic Centre, JLN Marg,
New Delhi -110002.

Subject: Examination of building plans from fire safety point of view in r/o Delhi Public School, Plot No-2, Sector-24, Delhi.

Sir,

Please refer to your online request ID No-10122091 dated 05.06.2026 on the subject cited above. In this connection, it is to inform you that the matter has been examined and the following shortcomings have been observed:

1. An all-around 06-meter-wide motorable road with a minimum turning radius of 09 meters for the movement of fire tenders has not been provided, as required under Clause 8.2 of UBBL-2016.
2. The travel distance from the dead end of the corridor does not meet the requirements of Clause 7.8.2 of UBBL-2016.
3. The width of the staircase is not in conformity with Clause 7.11.1(b) of UBBL-2016.
4. The width of exits/staircases has not been proposed in accordance with Clauses 8.4.3 and 7.23.2 of UBBL-2016.
5. The exits are not arranged in accordance with Clause 7.5.10 of UBBL-2016.
6. The address in the existing approved plan does not match the address shown in the proposed addition/alteration plan.

In view of the above, the building plans are **rejected**.

Yours faithfully,

16/6/26

(A. K. Malik)
Chief Fire Officer (HQ)
Delhi Fire Service