C-23

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI

No. F6/DFS/MS/EH/SZ/2026/900 Dated: / 01 / 10/2026

To,

The Commissioner MCD,
Civic Centre, Minto Road,
New Delhi- 110002.

Sub: Regarding issuance of FSC from fire safety point of view in r/o. M/s. Delhi Spice located at Prop. No.-95, First Floor, Shambhu Dayal Bagh, Old Ishwar Nagar, Okhla, New Delhi-110020.

Sir,

Please refer to your online application no. No. 2025061310001 dated- 21/08/2026, on the subject cited above. In this connection, it is to inform you that the premises was inspected by officer concerned of this department on 07/09/2026 Babu Ram (Manager) in the presence of Sh. Sunil Kumar to see the shortcomings already issued by this department. During inspection, the following shortcomings were observed.

1. Both the exits & staircases are on one side only & width of staircases 1.8m,1.1m, are provided against the requirement of 2m & 1.5m.
2. Fire Check door is not provided in kitchen.
3. MOEFA is not provided.
4. Overhead tank capacity of 20,000ltrs is not provided specially for restaurant only.

In view of above Shortcomings, the application for renewal of Fire safety Certificate is cannot considered at this stage & rejected. The occupancy of the building/premises in absence of requisites fire safety arrangements shall be at the risk and liabilities of the Owner/occupier.

Yours faithfully,

30/9/26.

(A.K. Malik)
Chief Fire Officer

Copy To: -

1. The Owner/occupier, M/s. Delhi Spice located at Prop. No.-95, First Floor, Shambhu Dayal Bagh, Old Ishwar Nagar, Okhla, New Delhi-110020. (Online application No. 2025061310001 dated- 21/08/2026