GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUATERS: DELHI FIRE SERVICE: NEW DELHI-110001

No: F.6/DFS/MS/CGHS/SZ/2026/330 Dated: - 31/07/2026

To,

The Chairperson,
Disaster Management Committe,
Dwarka District Courts, New Delhi.

Sub: - Regarding Inspection report/NOC in r/o District Court located at Sector-10, Dwarka, New Delhi.

Sir,

Please refer to your letter No. 7033/Disaster/Gen/DWK/2026 dated 08.06.2026, on the subject cited above. In this connection it is to inform you that the above said building/premises inspected by the officer concerned of this department, in the presence of Sh. Mohan Lal (JE, PWD) on dated 14.07.2026, to check the status of the shortcomings already pointed out by this department vide letter No. F.6/DFS/MS/SZ/2026/91 dated 30.03.2026 (copy enclosed), which are still not fully complied.

In view of the above, renewal of 'Fire Safety Certificate' cannot be considered at this stage. You are requested to rectify the above-mentioned shortcomings under intimation to this department for taking further necessary action in this matter,

Yours faithfully

Encl: - as above.

29/07/26

(S.K. Dua)
Chief Fire Officer
West Zone

Copy to:-

1. The Executive Engineer, PWD, District Courts, New Delhi.

C/1259

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/SZ/2026/ 91

Dated: 30 /03/2026

To,

The Administrative Officer (Judl),
District Courts, Dwarka,
New Delhi.

Subject: Inspection report/NOC in r/o District Court, Located at Sector -10, Dwarka, New Delhi.

Sir,

This has reference to meeting held on dated 07/02/2026 at 4 PM under chairmanship of Ld. ADJ, Dwarka Courts on the subject cited above. In this connection it is to inform you that the inspection of the Dwarka Court Complex was conducted by officer concerned of this department on 20/03/2026 along with Sh. Mohan lal (JE, PWD), Representative and observed that the shortcomings issued vide this office letter dated 21/07/2022 & 21/08/2023 (Copy enclosed) are still not complied.

1. The 6m wide motorable road all around the building found encroached / blocked.
2. The door closers of Fire check doors in all three buildings were found missing at some places and some fire check doors are found damaged.
3. Major addition /Alteration have been made at second floor in lawyers block and alternate exit has been blocked.
4. Some stairs are found closed in basement.
5. Manual Operated Electric Fire Alarm System, found nonfunctional in two blocks.
6. Open able windows are found replaced with fixed window in some stairs/ some areas in lawyer block /admin block.
7. Terrace pumps are found removed in lawyers block.
8. The sprinkler system must be extended in lawyers block & Admin block as provided in the court block.
9. The Hoses & branches are found missing from hose boxes.
10. The length of hose reel must be extended to 30 m so that the hose reel may cover entire area of the floor.
11. Smoke Exhaust system must keep in auto mode and interlinked with MOEFA & detectors and the damaged/ leaking ducts must be repaired/ replaced.
12. Pressurization system provided for lift shafts found nonfunctional and required to be put on auto mode.
13. The sprinkler nozzle in conference hall at 7th floor must be extended below false ceiling in court block.
14. On asking about the functioning PA system & Manual Call point PWD representative stated that the PA system & Manual call points are functional but it cannot be operate as the proceeding of the court is going on.

You are requested to direct the concerned officers to comply the abovementioned shortcomings under intimation to this department for further necessary action in the matter/renewal of fire safety certificate.

Yours faithfully,

(A.K. Malik)
Dy. Chief Fire Officer
South Zone

Copy to- The Executive Engineer, PWD, District Courts, New Delhi.