GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

आज़ादी का अमृत महोत्सव

No. F6 /DFS/MS/Mercantile/NDZ/2026/ 209 Dated: 30/05/2026

To

The Commissioner,
MCD, 9th floor, Civic Centre,
Minto Road, New Delhi.

Sub: - Regarding renewal of Fire Safety Certificate in r/o M/s DLF Gallaria Mall located at Plot no. 1B, District Centre, Mayur Vihar Ph-I, New Delhi.

Sir,

This has reference to the letter bearing outdoor diary no. 238 dated 08/04/2026 on the subject cited above. In this connection it is informed that the building was inspected by officer concerned of this department on 13.05.2026 in the presence of Mr. Rakesh Kumar (Property Manager) & Mr. Summit Dagar (Fire Officer) and following shortcomings were observed:

1. Smoke Management System found removed at upper floors.
2. Some of the Fire Check Door found non functional.
3. Pressurization of lift shaft and staircase found non functional at upper floor.
4. Pressurization of lift lobby in basement found removed.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

27/5/26
(Dr. S. K. Tomar)
Chief Fire Officer (NDZ)
Delhi Fire Service

Copy to:-

1. The Owner/Occupier/Manager, DLF Gallaria Mall located at Plot no. 1B, District Centre, Mayur Vihar Ph-I, New Delhi.