GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUATERS: DELHI FIRE SERVICE: NEW DELHI–110001

No. F.6/DFS/MS/Hospital/2025/SZ/ 621

Dated: 16/12/2025

To

The Assistant Engineer (E) HSW 2,
PWD EMESD South West,
E-mail: pwdemd3531@gmail.com
Deen Dayal Upadhyay Hospital,
Hari Nagar, New Delhi–110064

Sub: Regarding issuance of Fire Safety Certificate in r/o Doctors/Surgeons Block at DDU Hospital, Hari Nagar, New Delhi–110064

Sir,

This has reference to your letter F. No. 9(2)/AE(E)/HSW-2/PWDHMESD/DDUH/2025-26/136 dated 10/11/2025 received vide Diary No. 445/PD dated 12/11/2025. In this connection, it is to inform you that the said premise was inspected by the officer concerned of this department on 26/11/2025 in the presence of Sh. Subham & Ram Avtar (Fire Operators). During course of inspection, the shortcomings observed are as below.

1. One of the staircases found blocked/encroached & unusable.
2. Fire/Smoke check door found broken/defective at some places as indicated during inspection.
3. Sealing of electrical shaft not provided horizontally & vertically properly.
4. Hose-reel hose system at each floor found non-functional.
5. Manually operated electrical alarm system found partially functional.
6. Internal & yard hydrant system found non-functional & hose-boxes empty at 6th floor.

In view of the above, renewal of fire safety certificate cannot be considered at this stage. You are requested to rectify/submit compliance of the above-mentioned shortcomings under intimation to this department for further action in the matter.

Yours faithfully,

15/12/25

(A.K. Malik)
Dy. Chief Fire Officer (SZ)
Delhi Fire Service

Copy to: -

1. The Medical Superintendent, DDU Hospital, Hari Nagar, New Delhi–110064.