GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

आज़ादी का अमृत महोत्सव

No. F6/DFS/MS/WZ/2026/299 Dated: - 20/07/2026

To,

The Authorized Signatory,
Dr. B. R. Ambedkar Hospital,
Sector-6, Rohini, Delhi-110085.

Subj.:- Regarding renewal of Fire Safety Certificate in respect of Dr. B. R. Ambedkar Hospital, located at Sector-6, Rohini, Delhi-110085.

Sir,

This has reference to DFS online portal application no. 52026060903556 on the subject cited above. In this connection, it is to inform you that the said building was re-inspected by the officer concerned of this department on 02/07/2026 in the presence of Sh. Iqbal, J.E. to check compliance of shortcomings issued by this department vide letter no. F6/DFS/MS/WZ/Hospital/2025/270 dated 11/06/2025.

During the course of inspection, it has been observed that the hospital management has rectified some of the shortcomings, the status is under as: -

S. no.	Shortcomings	Status
1.	Alternate exits on all floors of ward block found permanently locked and filled with storage material and condemned items/equipment	Rectified
2.	Sprinkler found missing in whole central block	Not yet rectified
3.	FCD closer found damaged in many areas	Not yet rectified
4.	No fire safety officer found appointed under section 2q (g) being hospital building more than 500 beds despite many follow ups.	Not yet rectified
5.	Smoke management system is not sufficient and required to be reviewed with certified consultant and available smoke management system was not in auto mode.	Not yet rectified
6.	Hose-reel length is not found accessible in all the areas, therefore, length of hose-reel is required to be increased and one additional hose is required to be provided in hose-boxes	Not yet rectified
7.	Manual operated electrical alarm system found non operation in some areas	Rectified

In view of the above, the application for renewal of Fire safety Certificate cannot be considered at this stage & **rejected**. You are advised to rectify the above-mentioned shortcomings under intimation to this department & till such time occupancy of the building/premises in absence of requisite fire safety arrangements shall be at your own risk and responsibility.

Yours faithfully,

20/07/26

(S.K. Dua)
Chief Fire Officer
Delhi Fire Service