C-33

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110 001

No. F.6/DFS/MS/School/2025/NDZ/831 Dated: 24/11/2025

To,

The Principal,
Dr. Zakir Husain Memorial Senior Sec. School, Jafrabad,
Delhi-110053.

Sub: - Regarding renewal of Fire Safety Certificate r/o Dr. Zakir Husain Memorial Senior Sec. School, Jafrabad, Delhi-110053

Sir,

With reference to your letter no. DZHS/D/DFS/FC/25/392 dated 18/09/2025 on the subject cited above. In this connection, it is to inform you that officer concerned of this department has visited the premises on dated 14/11/2025 in presence of Sh. Riaz Ull Hasan, Principal. The building comprised of Ground plus three upper floors. Following shortcomings were observed during the time of inspection.

1. Overhead tank capacity 2,000 liters is provided against the requirement of 10,000 liters.

In view of the above, the building cannot be considered for renewal of Fire Safety Certificate at this stage. Therefore, you are requested to rectify the above-mentioned shortcomings under intimation to this office for further course of action.

Yours faithfully,

21/11/25

(Dr. S. K. TOMAR)
DY. CHIEF FIRE OFFICER (NDZ)
DELHI FIRE SERVICE

Copy to:-

The Dy. Director of Education, B-Block, Yamuna Vihar, Delhi-110053