C113

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No. F.6/DFS/MS/BP/2026/157 Dated: 21/02/2026

To

The Executive Engineer (Bldg.) HQ,
Municipal Corporation of Delhi,
8th Floor, Civic Centre, JLN Marg,
New Delhi- 110002.

Sub:- **Rejection** of building of building plans from fire safety point of view in r/o Mercantile Occupancy at E-18, Hauz Khas Market, New Delhi.

Sir,

With reference to request ID no. 10121578 dated 07.02.2026 on the subject cited above; it is informed that the referred online building plans in respect of proposed construction of Mercantile Occupancy at E-18, Hauz Khas Market, New Delhi were scrutinized under rule 34 of The Delhi Fire Service Rules, 2010 and following shortcomings were observed:-

1. 6 meter wide road along with 9m turning radius for fire tender movement are not proposed as per clause 8.2 of UBBL-2016.
2. Fire prevention & fire safety measures are not proposed as per NBC-2016, Part-IV/UBBL-2016.

In view of the above, the building plans are **rejected** with a request to resubmit plans after rectification of above shortcomings for further consideration in the matter.

Yours faithfully,

(M. K. Chattopadhyay)
Dy. Chief Fire Officer
Delhi Fire Service