C-86

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

आज़ादी का अमृत महोत्सव

No. F6/DFS/MS/GH/SZ/2026/ 112

Dated 09/02/2026

To,

The Commissioner,
Municipal Corporation of Delhi,
Civic Center, New Delhi – 110002.

Subject: - Regarding grant of Fire Safety Certificate in r/o McDonald's Restaurant located at Plot No. 2, Community Centre, Saket, New Delhi – 110017.

Sir,

This has a reference to MHA application No. 2026010900309 dated 10/01/2026, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 28/01/2026 in the presence of Mr. Pradeep (Area Manager) and observed that building comprised of Basement, Ground plus three upper floors Restaurant running on Ground & first floor only. Following shortcomings were observed during time of inspection:

1. Only One staircase of width 1.25 meters provided and second staircase of width 0.85 meter found removed which needs to be provided.
2. Exit & floors Signage's not provided in strategic location in the building.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is **rejected.** The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

9/2/26

A.K. Malik
Dy. Chief Fire Officer
Delhi Fire Service
O/C (W)