GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

आज़ादी का अमृत महोत्सव

No. F.6/DFS/MS/EH/SZ/2026/ 66 Dated: 21 / 01 /2026

To,

The Commissioner,
Municipal Corporation of Delhi,
Civic Centre, Minto Road,
New Delhi - 110002.

Subject: - Regarding grant of Fire Safety Certificate in r/o M/s Evergreen Sweets House located at S – 29 & 30, Green Park Market, New Delhi – 110016.

Sir,

This has a reference to your MCD Application No. 2026010600131 dated 06/01/2026, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officers concerned of this department on 10/01/2026 in the presence of Mr. Yatin Chopra (Owner) and observed that building comprised of Basement (Store), Ground floor (Shop), plus three upper floors, but restaurant ruining on first floor and second floor only & third floor (Vacant).

Following shortcomings were observed during time of inspection:

1. Fire Check door found removed in basement.
2. MOEFA provided but not functional.
3. Frist Aid hose reel, Automatic Sprinkler system and Internal Hydrant provided but nonfunctional.
4. Terrace Level Pump provided but not functional.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

21/1/26

A. K. Malik
Dy. Chief Fire Officer
Delhi Fire Service

Copy to: -

1. The Commissioner, Municipal Corporation of Delhi, Civic Centre, Minto Road, New Delhi - 110002.