C-46

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

आज़ादी का अमृत महोत्सव

No. F6/DFS/MS/BNQT/EH/WZ/2026/393 Dated: 28/04/2026

To,

The Commissioner,
Municipal Corporation of Delhi,
Civic Center, New Delhi – 110002.

Subject: - Regarding renewal of Fire Safety Certificate in r/o FFH Grand (A Unit of B.K Enterprises), located at A3, Chote Lal Park, Main Najafgarh Road, Kirti Nagar, New Delhi-110015.

Sir,

This has a reference to MCD application No. 2026040404272 dated 04/04/2026, on the subject cited above. In this connection, this is to inform you that the above-mentioned premises was visited by the officer concerned of this department on dated 15/04/2026 in the presence of Mr. Manu Bhatiya to verify the present status of fire safety measures installed in the building. The fire safety arrangements were tested / checked and found following observation: -

1. First-Aid-Hose Reel provided but not functional.
2. Internal hydrant provided but not functional.
3. Terrace fire pump of capacity 450 LPM provided but not functional.
4. Exit & floors Signage's not provided.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is **rejected.** The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

28/04/26

(S. K. Dua)
Chief Fire Officer
Delhi Fire Service

Copy to :

1. The Dy. Health Officer, MCD, West Zone, Vihar Enclave, Rajouri Garden, New Delhi-110027. (dhowest zone@gmail.com).
2. The Owner/Occupier, FFH Grand (A Unit of B.K Enterprises), A3, Chote Lal Park, Main Najafgarh Road, Kirti Nagar, New Delhi-110015.