c/128

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

आजादी का अमृत महोत्सव

No. F6/DFS/MS/GH/NDZ/2026/ 516 Dated: 27/05/2026

To,

The Commissioner,
Municipal Corporation of Delhi,
Civic Centre, Minto Road,
New Delhi

Sub: Regarding renewal of Fire Safety Certificate in r/o M/s Florence Legacy Guest House, 8456, Arya Nagar, Paharganj, New Delhi - 110055.

Sir,

Please refer your online application ID No. 2026050106171 dated 05/05/2026 on the subject cited above. In this connection, it is to inform you that the said building was inspected by the officer concerned of this department on 18/05/2026 in the presence of Sh. Umesh, Manager and following shortcomings were observed: -

1. Manually Operated Electronic Fire Alarm (MOEFA) provided but found non-functional.
2. Public Address system provided but found non-functional.
3. Automatic detection system provided but found non-functional.
4. Automatic operation of Fire pump found removed.
5. Domestic connection provided in Overhead Water storage tank is not permissible.

Keeping in view of the above **shortcomings**, the application for renewal of Fire Safety Certificate cannot be considered at this stage and stands **rejected**. Further, the occupancy of the building premises in the absence of requisite fire safety measures shall be at the risk and liability of the owner/occupier.

Yours Faithfully,

26/5/26

(Dr. S. K. Tomar)
Chief Fire Officer
Delhi Fire Service

Copy to: -

1. The Manager, M/s Florence Legacy Guest House, 8456, Arya Nagar, Paharganj, New Delhi - 110055.