GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No: F6/DFS/MS/NZ/2026/ 274

Dated: 07/07/2026

To,

Sh. S.S. Parihar, IAS
District Magistrate,
District Central North,
DM Office Complex, Lawrence Road,
Rampura, Delhi - 110035

Sub: - Inspection report in r/o M/s Fortis Hospital located at A Block, Shalimar Bagh, New Delhi.

Sir,

This has reference to order issued under the letter no. F.DM/Central North/Inspection/2026/149-167 dated 24/06/2026 on the subject cited above. In this connection it is to inform you that as directed the above said Hospital has been inspected by the designated team of officers i.e. SDM, DPO, Asst. Commissioner (MCD), CDMO, DFS etc concerned of this department on 25/06/2026 at 11.00 hours along with the representatives of Hospital and the following observations were made from fire safety point of view: -

1. Internal road of 6 m width for fire tender movement at under construction side area found blocked.
2. Unauthorized and unarranged parking found placed which can affect the fire tender movement in case of fire.
3. Fire check door leading to open terrace area of 5th floor level near lift lobby found closed/ under lock and key which need to be kept open all the time.
4. Lift lobby in basement found stored with locker's/ almirahs, which needs to be shift to other designated places.

The occupancy of the Building/ Premise in absence of requisites fire safety arrangements shall be at the risk and liabilities of the Owner/ Occupier.

This is for your kind information and further necessary action please.

Yours Faithfully

4/7/26

(Dr. S.K. Tomar)
Chief Fire Officer
Delhi Fire Service