GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No F.6/DFS /MS/2026/Cinema/WZ/ 96 Dated 22/05/2026

FIRE SAFETY CERTIFICATE

Certified that G3S Cinema Hall located at Plot No-6, 2nd floor, Sector-11, Rohini, Delhi-110085 comprised of Basement, Ground & 04 upper floors, **But (02 New Audi purposed at 2nd Floor, Audi No-4 & Audi No-5 only)** owned/occupied by G3S Cinema Hall have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officers concerned of Fire Service on 15/05/2026 in presence of Sh. Padminder Bisht (Manager) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of Delhi Fire Service Rules 2010 and that the premise is fit for occupancy class "Assembly **(Cinema, Audi No-4 & Audi No-5 only)**" with effective from 22/05/2026...for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subjected to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010 subject to conditions as mentioned below.

Issued on 22/05/2026 at New Delhi by.

22/05/26
(S.K. Dua)
Chief Fire Officer
Delhi Fire Service

Copy to :-

1. The Authorized Signatory, G3S Cinema Hall located at Plot No-6, 2nd floor, Sector-11, Rohini, Delhi-110085.
2. SDM, Rohini, District-North West, Room No-37, Kanjhawla, Delhi-110081.

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape shall be kept free from any type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipment and method of smooth and speedy safe evacuation of occupants in case of emergency
3. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seem during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities. This Fire Safety Certificate is valid only for permanent building structure as per plan.
5. This fire safety certificate may not be treated in any case of regularizations of unauthorized construction/unauthorized use of land or activities, if any.
6. Basement shall not be used for any other purpose except as specified in UBBL, subject to permission from concerned local authority.
7. The owner / occupier shall submit a declaration **every year** in **Form "K"** provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on the official website of Delhi Fire Service i.e. www.dfs.delhigovt.nic.in.
8. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in **Form 'J'** [sub rule (1) of rule 37] along with a copy of this Certificate, **six months** prior to its expiry".

INSPECTION REPORT

1. Name & address of the building : G3S Cinema Hall at Plot No-6, 2nd floor, Sec-11, Rohini, Delhi-110085.
2. Type of Occupancy : Assembly (Cinema Hall)
3. Composition of building : Basement, Ground & 04 upper floors, But **(02 New Audi purposed at 2nd Floor, Audi No-4 & Audi No-5 only)**
4. Type of Case : New case
5. Details of previous NOC : Nil
6. Fire Safety directives letter No : F.6/DFS/MS/BP/2018/44 Dated: 07/02/2018
7. Date of inspection : 15/05/2026
8. Name of the Inspecting Officers : ADO (Rohini) & DO (NW)
9. Name and designation of officers from the building side : Sh. Padminder Bisht (Manager)
10. Year of Construction : 2025
11. Applicant's letter No. : SDM/R/Misc/2025/1590-1595 dated 06/04/2026

S. no	Minimum Standards on fire prevention and fire safety U/R 33	As Per directives dated 07/02/2018	Provided at site	Remarks MR/NMR
1	**Access to building**			
	• Road width	Accessible	Accessible	MR
	• Gate width	06m	Provided	MR
	• Width of internal road	06m	Provided	MR
2	**Number, Width, Type & Arrangement of Exits**			
	a. Number of staircases			
	• Upper Floors	02	03	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	02m each	02m each	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	Required	Provided	MR
	e. Width of Corridor	1.50m	Provided	MR
	f. Door Size	1.50m	Provided	MR
3	**Compartmentation.**			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	**Smoke Management System.**	Common with the mall		
	• Basements	30 a/c per hour	Exhaust Fan	MR
	• Upper floors	12 a/c per hour	Natural ventilation	MR
5	**Fire Extinguishers**			
	• Total numbers	30nos	Provided	MR
	• Types	ABC/Wco2/Co2	Provided	MR
	• ISI marking	Yes	Provided	MR

6	**First-Aid Hose Reels.**	Common with the mall		
	• Total numbers on each floor	02	Provided	MR
	• Length of hose reel hose	30m	Provided	MR
	• Nozzle diameter	5mm	Provided	MR
7	**Automatic fire detection and alarming system.**	Common with the mall		
	• Type of detectors	Required	Provided	MR
	• Location of Main Panel	Required	Provided	MR
	• Location of Repeater Panel	Required Each floor	Provided	MR
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	Common areas	Provided	MR
8	**MOEFA**	Required	Provided	MR
9	**Public Address System.**	Required	Provided	MR
10	**Automatic Sprinkler System.**	Common with the mall		
	• Basement	NA	NA	NA
	• Upper Floor	Required	Provided	MR
	• Sprinkler above false ceiling	NA	NA	NA
11	**Internal Hydrants**	Common with the mall		
	• Size of riser/down-comer	150mm	Provided	MR
	• Number of hydrants per floor	02	Provided	MR
	• Hose Box	02	Provided	MR
12	**Yard Hydrants**			
	• Total number of hydrants	Required	Provided	MR
	• Hose Box	Required	Provided	MR
13	**Pumping Arrangements.**	Common with the mall		
	• Ground Level			
	➢ Discharge of main Pump	2280 LPM	Provided	MR
	➢ Head of Main pump	60m	Provided	MR
	➢ Number of main pumps	03	Provided	MR
	➢ Jockey Pump out put	180 LPM	Provided	MR
	➢ Jockey pump head	60m	Provided	MR
	➢ Standby Pump out put	2280 LPM	Provided	MR
	➢ Standby Pump Head	60m	Provided	MR
	➢ Auto Starting/ Manual stopping	Required	Provided	MR
	➢ Pump House Access			
	• Terrace level			
	➢ Discharge of pump	NA	NA	NA
	➢ Head of the pump	NA	NA	NA
	➢ Power Supply	NA	NA	NA
	➢ Auto Starting of pump	NA	NA	NA
14	**Captive Water Storage for fire fighting.**	Common with the mall		
	• Underground tank capacity	2,50,000 LTR	Provided	MR
	➢ Draw-off connection	Required	Provided	MR
	➢ Fire service inlet	Required	Provided	MR
	➢ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	30,000 LTR	Provided	MR

15	**Exit Signage.**	Required	Provided	MR
16	**Provision of Lifts.**	Common with the mall		
	• Pressurization of Lift Shaft	Required	Provided	MR
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	Required	Provided	MR
	• Fireman's Grounding Switch	Required	Provided	MR
	• Lift Signage	Required	Provided	MR
17	**Standby power supply**	Required	Provided	MR
18	**Refuge Area.**			
	➢ Total Area	NA	NA	NA
	➢ Location	NA	NA	NA
19	**Fire Control Room**			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	Required	Provided	MR
	• Batter backup	Required	Provided	MR
	• Building Floor Plans	Required	Provided	MR
20	Special Fire Protection Systems for Protection of special Risks, if any:	Required	Provided	MR

Note:- The observations/ shortcomings issued and communicated vide this department letter of even no. F6/DFS/MS/2026/Cinema/WZ/181 dated 14/05/2026 have been complied by the management.

The fire protection systems provided in the building were tested/ checked randomly and found functional at the time of inspection.

Keeping in view of satisfactory compliance of the minimum standards of fire prevention and fire safety measures required under the rules, **it is recommended to Grant of Fire Safety Certificate.**

18/05/2026
Signature of the inspection Officer
Name :- C.L. Meena
Designation:- ADO/Rohini

18/05/2026
Signature of the Inspecting Officer
Name:- A.K. Jaiswal
Designation:- DO/NW

CFO/(WZ)

19/05/26

Pr. Director

CFO to [illegible]

20/05/26

F.T. Please.

CFO (WZ)

21/05/26

ADO (Rohini)