C-12

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

आज़ादी का अमृत महोत्सव

No. F6/DFS/MS/School/NDZ/2025/802 Dated: 11/11/2025

To

The Principal,
Geeta National Public School,
I-193, Lalita Park, Laxmi Nagar,
Delhi-94.

Sub: Regarding issuance of Fire Safety Certificate in respect of Geeta National Public School located at I-193, Lalita Park, Laxmi Nagar, Delhi-92.

Sir,

With reference to the email dated 13.10.2025 on the subject cited above, it is informed that the said school was visited by officer concerned of this department on 01.11.2025 in the presence of Sh. Mahender (Caretaker) and it was observed that the shortcomings issued to the school vide letter no. F6/DFS/MS/School/NDZ/2025/257 dated 22.04.2025 have not been rectified till date. Hence issuance of Fire Safety Certificate to the school cannot be considered at this stage.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

10/11/25

(Dr. S. K. Tomar)
Dy. Chief Fire Officer (NDZ)

07/11/25

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No. F6/DFS/MS/School/NDZ/2025/257 Dated: 22/04/2025

To,

The Principal,
Geeta National Public School
I – 193, Lalita Park, Laxmi Nagar,
Delhi - 110094.

Subject: - Regarding grant of Fire Safety Certificate in r/o Geeta National Public School located at I – 193, Lalita Park, Laxmi Nagar, Delhi - 110094.

Sir,

This has a reference to your Outdoor Diary No. 15125 dated 28/03/2025, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 12/04/2025 in the presence of Mrs. Hemlata (Principal) and observed that building comprised of ground plus three upper floors.

Following shortcomings were observed during time of inspection:

1. One staircase of width 0.90 meter is provided in building instead of required 02 nos. of staircase of width 1.50 meter each.
2. Door size of 0.85 meter provided against requirement of 1.20 meter.
3. All fire extinguishers not provided.
4. First-Aid-Hose Reel not provided.
5. Terrace level fire pump capacity of 450 LPM not provided.
6. Overhead tank of capacity 10,000 litters not provided.
7. Exit & floors Signage's not provided at strategic location in the building.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR
O/C DELHI FIRE SERVICE

Copy to:-

1. The Director of Education, East Delhi Municipal Corporation, 419, Udyog Sadan, Patparganj Industrial Area, Delhi - 110092.