GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

आज़ादी का अमृत महोत्सव

No. F6/DFS/MS/BNQT/WZ/2026/862 Dated: 10/09/2026

To,

The Commissioner,
Municipal Corporation of Delhi,
Civic Center, New Delhi – 110002.

Subject: - Regarding renewal of Fire Safety Certificate in r/o M/s Golden Gate Banquet Hall located at Plot No. B-18, Maya puri, New Delhi.

Sir,

This has a reference to MCD application No. 2026073110205 dated 31/07/2026, on the subject cited above. In this connection, this is to inform you that the above mentioned premises was visited by the officer concerned of this department on dated 10/08/2026 in the presence of Mr. Rohit Kalra (Owner) to verify the present status of fire safety measures installed in the building. The fire safety arrangements were tested / checked and found following observation:-

1. Smoke management system found removed in basement and upper floors.
2. Overhead water tank of capacity 20,000 lit. provided against the requirement of 25,000 litr.
3. Exit signage not provided at strategic location in the building.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is **rejected.** The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(A.K. Malik)
Chief Fire Officer
Delhi Fire Service

Copy to :

1. The Owner/Occupier, M/s Golden Gate Banquet Hall, Plot No. B-18, Maya puri, New Delhi.