c139

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUATERS: DELHI FIRE SERVICE: NEW DELHI–110001

No. F.6/DFS/MS/School/2025/SZ/ 876 Dated: 08/12/2025

To

Principal/Manager,
Golden Valley Sr. Sec. Public School,
A–161, Todarmal Colony,
Najafgarh, New Delhi–110043

Sub: Renewal of Fire Safety Certificate in r/o Golden Valley Senior Secondary Public School located at A–161, Todarmal Colony, Najafgarh, New Delhi–110043

Sir,

This has reference to your letter No. GVSSPS/2025/11/1756 dated 03/11/2025, received in this department vide outdoor diary No. 8065 dated 10/11/2025. In this connection, it is to inform you that the premise was inspected by the officer concerned of this department on 28/11/2025 in the presence of Sh. Anil Sharma (Principal) of the school. During course of inspection, the shortcomings observed are as below.

1. Hose-reel hose found provided but non-functional.
2. Terrace level fire pumps found provided but non-functional.
3. Overhead water storage tank for fire-fighting found empty.
4. Exit signage's found removed at some locations.

In view of the above, renewal of fire safety certificate cannot be considered at this stage. You are requested to rectify/submit compliance of the above-mentioned shortcomings under intimation to this department for further action in the matter.

Yours faithfully,

5/12/25

(A.K. Malik)
Dy. Chief Fire Officer (SZ)
Delhi Fire Service

9/12

Copy to: -

1. Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi–110054.