C-55

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

आज़ादी का अमृत महोत्सव

No.F6/DFS/MS/EH/SZ/2026/ 754 Dated: 11/11/2026

FIRE SAFETY CERTIFICATE (FSC)

Certified that M/s Gong (A Unit of Speciality Restaurants Limited) is running on Ground floor of the building which is comprised of Basement + Ground + 01 upper floor located at Property No. Plot No 11, Sec- C, Pocket- 6 & 7, Local Shopping Centre, Vasant Kunj, New Delhi – 110070, occupied by Gong (a Unit of Speciality Restaurants Limited) was earlier issued Fire Safety Certificate by this Department in the name of M/s Barbeque Nation vide letter No. F.6/DFS/MS/EH/SZ/2025/188 dated 13.05.2025. The Restaurant was re-inspected by the officer concerned of this Department on 03.11.2026 in presence of Sh. Aditya (Project Manager) and it was found that the Restaurant has complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the building/premises (Ground floor only) is fit for occupancy class Group 'D' Assembly (Eating House) at Ground floor, with effect from.....11.11.2026. for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to conditions under Rule 38 of Delhi Fire service Rules, 2010 printed below.

Issued on .....11.11.2026.....at New Delhi by

10/11/26

(A. K. Malik)
Chief Fire Officer
O/c 11/11/26

Reference: MCD/MHA application No. 2026082710740 & 2026090210850 & 2026101611264.

Copy to:

1. The Commissioner, MCD, 9th floor, Civic Centre, Minto Road, New Delhi.
2. The Owner/Occupier/Manager, M/s Gong (A Unit of Speciality Restaurants Limited located at Plot No 11, Sec- C, Pocket- 6 & 7, Local Shopping Centre, Vasant Kunj, New Delhi – 70.

Conditions for the validity of Fire Safety Certificate

1. This Fire Safety Certificate is valid for Eating House at Ground floor only.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
3. Any loss of life or property due to nonfunctional fire safety measures shall be at the responsibility of the management.
4. The trained firefighting staff should be available round the clock.
5. Use of the basement shall be as per UBBL 2016.
6. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
7. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
8. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.
9. The means of escape shall be kept unobstructed/unlocked for unhindered evacuation in case of an emergency.
10. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub Rule (I) of Rule 37] along with a copy of this Certificate, six month prior to its expiry. Any change in the occupancy shall be intimated to this Deptt. and approval shall be obtained thereto before occupancy of the same.

INSPECTION REPORT					
1.	Name and address of the building:		**M/s Gong (A Unit of Speciality Restaurants Limited)** located at **Ground floor** of Plot No 11, Sec- C, Pocket- 6 & 7, Local Shopping Centre, Vasant Kunj, New Delhi – 70.		
2.	Building is comprised of		**Basement + Ground + 01 upper floor** Restaurant running at Ground floor of the building.		
3.	Type of occupancy		Group D -Assembly (Eating House)		
4.	Type of case:		Renewal.		
5.	Details of previous FSC:		F.6/DFS/MS/EH/SZ/2025/188 dated 13.05.2025(Barbeque Nation)		
6.	Fire safety directives No.:		NA		
7.	Date of inspection:		03/11/2026		
8.	Name of the inspecting officer:		Rajesh Kumar Shukla, ADO (Jangpura)		
9.	Name and designation of the officer from the building side:		Mr. Aditya (Project Manager)		
10	Year of construction:		2005 (As per the MCD/MHA online application)		
11	Reference letter No.:		MCD/MHA application No. 2026082710740 & 2026090210850 & 2026101611264		
S.No	**Minimum standard of Fire Prevention and Fire Safety U/R 33**		**Requirements (As per NBC/UBBL-2016)**	**Provide at site**	**Remarks MR/NMR**
1	**Access to Building:**				
	A	Road width	6.0 mtrs.	Provided	MR
	B	Gate width	NA	NA	NA
	C	Width of internal roads	NA	NA	NA
2	**Number, Width, Type & Arrangement of Exits:**				
	A	No. of Staircase:	**Restaurant at Ground floor only**		
		a) Upper floor	NA	NA	NA
		b) Basements	NA	NA	NA
	B	Width of the Staircase	**Restaurant at Ground floor only**		
		a) Upper floors	NA	NA	NA
		b) Basements	NA	1.25 m and 1 m	NA
	C	Protection of Exits			
		a) fire check door	NA	NA	NA
		b) pressurization	NA	NA	NA
	D	No. of continuous staircase to terrace	NA	NA	NA
	E	Width of the corridor	NA	NA	NA
	F	Door size (Exit)	2.0 m & 1.50 m	2.2 m, 2.0 m, 1.30 m, 1.10 & 0.80 m	MR
3	**Compartmentation:**				
	A	Fire check doors	Required in Kitchen	Provided	MR
	B	Sealing of horizontal & vertical opening	NA	NA	NA
	C	Fire rating of shaft doors	NA	NA	NA
	D	Water curtain	NA	NA	NA
	E	Fire dampers	NA	NA	NA
4	**Smoke Management System:**				
	A	Basements	NA	NA	NA
	B	Upper floors/Restaurant	Mechanical/ Natural	Exhaust fans	MR
5	**Fire Extinguishers:**				
	A	Total numbers	04 No.	06 nos.	MR
	B	Types	ABC +CO_2	ABC +CO_2	MR
	C	ISI marking	ISI marked	ISI marked	MR

N/15

6	**First Aid Hose Reel:**				
	A	Total No. at each floor	01 No.	01 No.	MR
	B	Length of hose reel	30 m	30 m	MR
	C	Nozzle diameter	5 mm	5 mm	MR
7	**Automatic Fire Detection and Alarm System (ADAS):**				
	A	Type of detectors	NA	Smoke & heat	NA
	B	Location of main panel	NA	GF floor	NA
	C	Location of repeater panel	NA	NA	NA
	D	Alternate power source	NA	Provided	NA
	E	Hooter's location	NA	Provided	NA
8	**MOEFA:**		Required	Provided	MR
9	**Public Address System:**		NA	NA	NA
10	**Automatic Sprinkler System:**				
	A	Basement	NA	Provided	NA
	B	Ground floor/Upper floor	NA	Provided	NA
	C	Sprinklers above false ceiling	NA	NA	NA
11	**Internal Hydrants:**				
	A	Size of down comer	100 mm	100 mm	MR
	B	No. of hydrants per floor	1 No.	2 No.	MR
	C	Hose box	1 No.	2 No.	MR
12	**Yard Hydrants:**				
	A	Total No. of hydrants	NA	Provided	NA
	B	Hose box	NA	Provided	NA
13	**Pumping arrangements:** (Common firefighting system provided & maintained by building management)				
	A	Ground Level			
		a) Discharge & head of main pump	NA	1850 LPM & 60 m	NA
		b) Number of main pumps	NA	2 No. (1850 LPM and 1320 LPM)	NA
		c) Discharge & head of jockey pump	NA	180 LPM & 60 m	NA
		d) Discharge & head of standby pump	NA	NA	NA
		e) Auto starting/ manual stopping	NA	Provided	NA
	B	Terrace Level: (Common fire fighting system provided & maintained by building management)			
		a) Discharge of terrace pump	450 LPM	As above	MR
		b) Head of terrace pump	40 m	As above	MR
		c) Alternate power supply	Required	As above	MR
		d) Auto starting of pump	Required	As above	MR
14	**Captive Water Storage for Fire Fighting:**				
	A	Underground tank capacity	NA	1,00,000 ltrs	NA
	B	Draw off connection	NA	Provided	NA
	C	Fire service inlet	NA	Provided	NA
	D	Access to tank	NA	Provided	NA
	E	Overhead tank capacity	20,000 Liters	As above	MR
15	**Exit Signage:**		Required	Provided	MR
16	**Provision of lift:**				
	A	Pressurization of lift shaft	NA	NA	NA
	B	Pressurization of lift lobby	NA	NA	NA
	C	Communication in lift car	NA	NA	NA
	D	Fireman switch	NA	NA	NA
	E	Lift signage	NA	NA	NA
17	**Standby Power Supply:**		Required	Provided	MR
18	**Refuge Area:**				
	A	location	NA	NA	NA
	B	Total area	NA	NA	NA

N/16

M/s Gong (A Unit of Speciality Restaurants Limited located at Plot No 11, Sec- C, Pocket- 6 & 7, Local Shopping Centre, Vasant Kunj, New Delhi – 70.

19	**Fire Control Room:**				
	A	Fire detection system panel	NA	NA	NA
	B	Flow switch panel	NA	NA	NA
	C	P a system panel	NA	NA	NA
	D	Battery backup	NA	NA	NA
	E	Building floor plan	NA	NA	NA
20	**Special Fire Protection for special risk if any**				
	A	Special Fire Protection system for Protection of Special Risk, if any:			NA

LEGENDS:-Meeting Requirement (MR), Not Meeting Requirement (NMR), Not Applicable (NA), Not Provided (NP) Provide But Not Functional (PNF).

Note: The composition of the building in the ealier inspection reports has been mentioned as Basement + Ground + 2 upper floors. However, the composition of the building as observed during this inspection is Basement + ground + 1 upper floor only. Two separate Restaurants namely Barbeque Nation and Monkey Bar operating at Ground and 1st floor respectively had already been issued Fire Safety Certificate from this Department which is valid till date. The fixed fire installation has been provided & maintained by the building management which is common to the entire building. The installed fire system is of higher capacity and category then required for the individual restaurant and same was found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the Rules, it is recommended to renew the Fire Safety Certificate issued vide letter No. F.6/DFS/MS/EH/SZ/2025/188 dated 13.05.2025 under Rules 35(6) of Delhi Fire Service Rules 2010.

03/11/26

Signature of the Inspecting Officer
Name Rajesh Kumar Shukla
Designation ADO (Jangpura)

DO (South)

3/11/26
Ravinder Singh

Please clarify is this Restaurant is in addition to above two mentioned or a replacement of Barbeque Nation.

4/11/26
A.K. MALIK

5/11/26
Ravinder Singh

Its replacement of Barbeque Nation. Now Gong Restaurant has taken over the operation of Ground floor. Resubmitted plz

05/11/26.

DO (SD)

6/11/24
Ravinder Singh

CFO(S2)

6/01/26
A.K. MALIK

CFO to issue. 9/11/26

CFO(S2)

10/01/26
A.K. MALIK

MO(SD)

10/11/26

ADO (MB)

LT is put up, as approved

10/11/26

CFO(S2)

10/01/26
A.K. MALIK

M.S. cell

Uploaded
12/11/26