C97

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/GH/SZ/2026/ 482 Dated: 19/05/2026

To,

The Commissioner MCD,
Civic Centre, Minto Road,
New Delhi- 110002.

Sub: Inspection report in r/o M/s. Goodwill Hotel, (A unit of Goodwill apartment Pvt. Ltd.), located at E-82, Greater Kailash, Part-1, New Delhi 110048.

Sir,

Please refer to your online application no. 2026042205561 dated 22/04/2026, received through online portal, on the subject cited above. In this connection, it is to inform you that the premises was re-inspected by officer concerned of this department on 07/05/2026 in the presence of Sh. Milandeep Singh Joly to check the shortcoming already issued by this department vide letter No. F6/DFS/MS/GH/SZ/2026/369 dated 24/04/2026. (Copy enclosed)

The following shortcoming are still not complied: -

1. Alternate staircase was found removed in basement.
2. Smoke management system found removed in the basement.

In view of above Shortcomings, the application for Issuance of Fire safety Certificate is rejected. The occupancy of the building/ premises in absence of requisites fire safety Arrangements Shall be at the risk and liabilities of the Owner/occupier. The licensing issuing authority/statutory authority is requested that premises should not be allowed to run till it provide all necessary fire arrangements.

Yours faithfully

19/5/26

(A.K. Malik)
Chief Fire Officer

Copy to: -

1. The Owner/Occupier of M/s. Goodwill Hotel, (A unit of Goodwill apartment Pvt. Ltd.), located at E-82, Greater Kailash, Part-1, New Delhi 110048. (online application No.: - 2026042205561 dated 22/04/2026).