C/31

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001

No. F6/DFS/MS/School/2025/SZ/ 786 Dated: 23/10/2025

To,

The Principal
Govt. Co-ed. Sr. Sec. School,
Sector- 22, Dwarka, New Delhi- 110077.

Sub: - Regarding issuance of "FSC" from fire safety point of view in r/o Govt. Co-ed. Sr. Sec. School located at Sector- 22, Dwarka, New Delhi- 110077.

Sir,

Please refer to your letter No. S-22/DWK/2025-25/491, on the subject cited above. In this connection, it is to inform you that officer concerned of this department inspected the school building on dated 14.10.2025 to verify the fire safety arrangements in accordance with the rules. At the time of inspection Mr. Satyapal (Estate Manager) was present and it was observed that school building comprised of ground plus three upper floors, and have following shortcomings:-

1. Hose reels/hydrant found provided but not functional.
2. Terrace fire pump of 450 LPM found provided but not functional.
3. Exit signage's are not provided.

In view of the above, issuance of 'Fire Safety Certificate' cannot be granted at this stage. You are requested to rectify the above-mentioned shortcomings under intimation to this department for taking further necessary action in this matter and running school in absence of requisite fire safety arrangements shall be at the risk & liability of the school management.

Yours faithfully

21/10/25
(A.K. Malik)
Dy. Chief Fire Officer
South Zone

Copy to:-

1. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054