C-14

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI – 110001

NO. F6/DFS/MS/SZ/2026/ 167

DATED: 23/02/2026

The Assistant Engineer (E)
Edu.Sub-Divn M1-1,(N
PWD ITI Campus Pusa
New Delhi-110012

Subject: - Regarding issuance of Fire Safety Certificate in r/o Govt. Co-ed Sr. Sec. School Dwarka 16B, New Delhi

Please refer to your letter No. 54(SPS School)PWD Edu.Sub-Divn MI-1(N)/2025-26/16 dated 27/01/2026 on the subject cited above. In this connection it is to inform to you that the above said building has been inspected by the officer concerned of this department on 05/02/2026 & 09/02/2026 in presence of Sh. Shubham JE/Civil & Sh. Sudheer Pande (Engineer) from fire safety point of view.

During the course of inspection followings shortcoming are observed:-

1. Six meter wide internal road around the building found blocked/encroached.
2. Fire Check Doors found not provided.
3. The width of two exit gate for hall (4th Floor) is 2X118 cm against required width of 2X2 m.
4. Hose reel hose & hydrants found nonfunctional.
5. R.R.Hose Pipe & branch found not provided
6. Public address system & Moefa not Provided.
7. Fire extinguishers not provided
8. Terrace tank of 25000ltrs capacity found empty.
9. Terrace pump of capacity 900 lpm found nonfunctional.
10. Exit signage found not provided at some places.
11. Pressurization of Lift Shaft found nonfunctional.
12. Standby power supply not provided.
13. PA System Panel, Battery backup, Detector system panel & Building Floor Plans in fire control room found not provided.
14. Road Load capacity The 6 meter wide internal concrete road is structurally inadequate to sustain a heavy load of 45 Tons. This poses a risk of surface failure and blockage for emergency vehicles.

In view of the above shortcomings issuance of Fire Safety Certificate from fire safety point of view cannot be considered at this stage. You are requested to comply the above mentioned shortcomings under intimation to this department for further consideration in the matter.

(M.K.Chattopadhyay)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to:-

1. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054