C-24

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

आज़ादी का अमृत महोत्सव

No. F.6/DFS/MS/NDZ/2025/ 646 Dated: 29/12/2025

To,

The Assistant Engineer (E),
Government of India Press,
Minto Road, New Delhi -110002

Sub: Application for renewal of Fire Safety Certificate in r/o of Government of India Press at Minto Road, Pocket – II, DDU Marg, New Delhi.

Sir,

Please refer your application dated 28/10/2025 received in this department through outdoor diary No. 7532 dated 28/10/2025, on the subject cited above. In this connection, it is to inform you that the said building was inspected by the officers concerned of this department on 16/12/2025 in the presence of Mr. Mayank Routhan, A.E. (Electrical) CPWD and following shortcomings were observed: -

1. Manually Operated Electronic Fire Alarm (MOEFA) provided but found non-functional.
2. Exit signages/lift signage/ floor signage were found removed at some places.
3. Pressurization system installed in staircases, lift shafts and lift lobbies but found non-functional.
4. Vertical and horizontal openings found unsealed at some locations.
5. Smoke management system provided but found non-functional.
6. Self-closing devices of Fire check doors were found removed at some places.

Further, 5th & 6th floor could not be checked as both the floors were found locked.

In view of the above shortcomings, the application for renewal of fire safety certificate cannot be considered at this stage & stands **rejected**. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

29/12/25

(Dr. S. K. Tomar)
Dy. Chief Fire Officer

OIC BP