C-32

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI – 110001

No.F.6/DFS/MS/SZ/2025/ 848 Dated: 27 / 11 / 2025
2025

To,

The Principal,
Govt. Sarvodaya Bal vidyalaya,
Bijwasan Bharthal,
New Delhi.110077.

Subject: Renewal of Fire Safety Certificate in r/o Govt. Sarvodaya Bal vidyalaya,Located at Bijwasan Bharthal New Delhi.110077.(School ID-1821032

Sir,

Please refer to your Letter no :Bij/2025/534 Dated-18/08/2025 on the subject mentioned above. In this connection it is to inform you that the premises was inspected by the officer concerned from this department on 07/11/2025 in the presence of Sh. Shyam Sunder (St. Manager) from fire safety point of view.

During the course of inspection following shortcomings are observed:-

1. Hose reel found non functional due to nozzle missing.
2. Terrace level fire pump found nonfunctional.
3. Exit signage's found removed at some locations.

In view of the above shortcomings renewal of Fire Safety Certificate is rejected. & you are directed to comply the shortcomings under intimation to this department for further consideration in the matter.

Yours faithfully

28/11/25

(A.K. Malik)
Dy. Chief Fire Officer
South Zone

Copy to; -
The Directorate of Education, Old Secretariat, Delhi – 110054.