C-29

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No: F.6/DFS/MS/2025/WZ/851 Dated: 27/11/2025

To,

The Principal,
G.R. Memorial Sr. Sec. Public School,
Shiv Ram Park, Nilothi More,
Nangloi, Delhi-110041.

Sub:- Renewal of Fire Safety Certificate in respect of G.R. Memorial Sr. Sec. Public School located at Shiv Ram Park, Nilothi More, Nangloi, Delhi- 110041.

Sir,

This has reference to your Form J received through outdoor diary no. 7735 dated 03/11/2025 on the subject cited above. In this connection, it is to inform you that the inspection of above said school building has been carried out by officer concerned of this department on 17.11.2025 to see the compliance of the requisite fire safety measures. Mr. Jai Singh was present at the time of inspection.

During the course of inspection it was observed that the school building is comprised of Ground and Three upper floors. Your request for renewal of FSC is rejected as the following shortcomings were observed:-

1. Terrace level pump not found in auto mode.
2. Overhead tank of 6000 ltrs capacity found provided against the required capacity of 10,000 ltrs.
3. Exit signages found removed at some places.

You are advised to rectify the above-mentioned shortcoming for taking further action as necessary for renewal of Fire Safety Certificate.

Yours Faithfully

27/11/25

(S.K. Dua)
Dy. Chief Fire Officer
West Zone

Copy to :-

1. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi.