GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No. F6/DFS/MS/EH/SZ/2026/860 Dated 10 /09 /2026

To,

The Commissioner,
Municipal Corporation of Delhi,
Civic Center, New Delhi – 110002.

Subject: - Regarding grant of Fire Safety Certificate in r/o M/s Grand Elysium Restaurant located at Plot No. 22, GF & FF, Kh. No. 15, 119 - 20 & 16/16, Suraj Vihar, Kakrola, Dwarka, New Delhi – 110078.

Sir,

This has a reference to MCD application No. 2026080410281 dated 06/08/2026, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 25/08/2026 in the presence of Mr. Gaurav Wadhwa and observed that building comprised of Basement, Ground plus three upper floors only **But Restaurant running on ground floor only**, following shortcomings were observed during time of inspection:

1. The width of exits at each floor found 1.70 meters & 1.0 meters against required width 1.50 meters each.
2. First-Aid-Hose Reel provided but not functional.
3. MOEFA provided but not functional.
4. Internal Hydrants provided but not functional.
5. Terrace fire pump provided but not functional.
6. Exit & floors Signage's not provided in strategic location in the building.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is **rejected.** The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

9/9/26

(A.K. Malik)
Chief Fire Officer
Delhi Fire Service
O/C (W)

Copy to: -

1. The Owner, Grand Elysium Restaurant located at Plot No. 22, GF & FF, Kh. No. 15, 119 - 20 & 16/16, Suraj Vihar, Kakrola, Dwarka, New Delhi – 110078.