C-46

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001

No. F.6/DFS/MS/EH/2026/SZ/ 747 Dated: 13/10/2026

FIRE SAFETY CERTIFICATE

Certified that the M/s Grand Elysium Restaurant located at GF, Plot No. 22, Khasra No. 15/119-20 and 16/16, Suraj Vihar, Kakrola, Dwarka, New Delhi- 110078, running at ground floor only in a building comprised of basement, ground plus three upper floors, owned/occupied by M/s Grand Elysium Restaurant, have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010. and verified by the officers concerned of this department on dated 15.09.2026 in the presence of the Manager, and found that the building is fit for occupancy Class "D" "Assembly Building" (for restaurant running at ground floor only) w.e.f. 13|10|2026 with a period of three years, in accordance with Rule- 36 unless renewed under Rule- 37 or sooner cancelled under Rule- 40 and subject to compliance of the conditions under Rule-38 of the Delhi Fire Service Rules, 2010 printed below.

Issued on 13|10|2026 at New Delhi.

Anilash 13/10/26

(A.K.Malik)
Chief Fire Officer
Delhi Fire Service

Online application Id 2026082110605 dated 24.08.2026.

Copy to: - The Executive Engineer (Building), MCD, Civic Centre, Minto Road, New Delhi. : - **for information regarding use of basement and request to ensure the occupancy as detailed above and deviation, if any.**

Conditions for validity of Fire Safety Certificate:-

1. The FSC issued for eating house/ restaurant running at ground floor only.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
3. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
4. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
5. The trained staff should be available round the clock.
6. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
7. The basement is currently used for storage only.
8. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
9. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
10. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

N/B

INSPECTION REPORT

1. Name & address of the building : Grand Elysium Resuaurant at Plot No. 22, GF, Kh. No. 15/119-20 and, 16/16, Suraj Vihar, Kakrola, Dwarka, New Delhi- 110078.
2. Building is comprised of : Basement, ground plus three upper floors, **Restaurant running at ground floor only**
3. Type of Occupancy : Group D (Assembly)
4. Type of Case : New Case (Eating House)
5. Details of Previous NOC : N/A
6. Fire Safety directives letter No : N/A
7. Date of inspection : 15.09.2026
8. Name of Inspecting Officers : R.K. Yadav, ADO (DWK)
9. Name and designation of officers From the building side : Manager
10. Year of Construction : 2019 (As per online MCD application)
11. Applicant's letter No. : MHA Portal ID 2026082110605 dated 24.08.2026

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	UBBL/NBC- 2016 Requirement	Provided at site	Remarks MR/NMR
1.	**Access to building**			
	• Road width	06 m	Provided	MR
	• Gate width	4.5 m	Provided	MR
	• Width of internal road	N/A	N/A	N/A
2.	**Number, Width, Type & Arrangement of Exits**			
	a. Number of staircases	**Restaurant running at ground floor only**		
	• Upper Floors	N/A	N/A	N/A
	• Basements	N/A	N/A	N/A
	b. Width of staircases			
	• Upper Floor	N/A	N/A	N/A
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircases to terrace			
	e. Width of Corridor	N/A	N/A	N/A
	f. Door Size	N/A	N/A	N/A
		1.50 m each (02 nos.)	1.70 m & 1.50 m	MR
3.	**Compartmentation**			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	**Smoke Management System**			
	• Basements	N/A	N/A	N/A
	• Upper floors	12 ACPH	Natural Ventilation	MR
5.	**Fire Extinguishers**			
	• Total numbers in restaurant	08 no.'s	Provided	M/R
	• Types	ABC/CO_2	ABC- 04 & Co2- 04	M/R
	• IS marking	ISI marked	Provided	M/R
6.	**First-Aid Hose Reels**			
	• Total numbers at each floor	1 Nos.	Provided	M/R
	• Length of hose reel hose	30 m	Provided	M/R
	• Nozzle diameter	5 mm	Provided	M/R

N/20

7.	**Automatic fire detection and alarming system in restaurant**			
	• Type of detectors Smoke/Heat	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8.	**MOEFA**	Required	Provided	M/R
9.	**Public Address System**	N/A	N/A	N/A
10.	**Automatic Sprinkler System**			
	• Basement	N/A	N/A	N/A
	• Upper floors	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	**Internal Hydrants**			
	• Size of riser/down-comer	100 mm	100 mm	MR
	• Number of hydrants	01 no's	01 no's	MR
	• Hose Box	Required	Provided	MR
12.	**Yard Hydrants**			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13.	**Pumping Arrangements**			
	• Ground Level			
	➢ Discharge of main Pump	N/A	N/A	N/A
	➢ Head of Main pump	N/A	N/A	N/A
	➢ Number of main pumps	N/A	N/A	N/A
	➢ Jockey Pump out put	N/A	N/A	N/A
	➢ Jockey pump head	N/A	N/A	N/A
	➢ Standby Pump out put	N/A	N/A	N/A
	➢ Standby Pump Head	N/A	N/A	N/A
	➢ Water curtain Pump	N/A	N/A	N/A
	➢ Auto Starting/Manual Stopping	N/A	N/A	N/A
	➢ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➢ Discharge of pump	450 LPM	450 LPM	M/R
	➢ Head of the pump	40 m	40 m	M/R
	➢ Power Supply	Required	Provided	M/R
	➢ Auto Starting of pump	Required	Provided	M/R
14.	**Captive Water Storage for fire-fighting**			
	➢ Underground tank capacity	N/A	N/A	N/A
	Draw-off connection	N/A	N/A	N/A
	➢ Fire service inlet	N/A	N/A	N/A
	➢ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	20,000 ltrs	25,000 ltrs	M/R
15.	**Exit Signage.**	Required	Provided	M/R
16.	**Provision of Lifts**			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17.	**Standby power supply**	Required	Provided	M/R

N/21

18.	**Refuge Area.**			
	➢ Total Area	N/A	N/A	N/A
	➢ Location	N/A	N/A	N/A
19.	**Fire Control Room**			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20.	**Special Fire Protection System for Protection of special Risks, if any:**	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection. The shortcomings was issued by this department vide letter No. F6/DFS/MS/EH/SZ/2026/860 dated 10.09.2026 have been rectified.

Note: - As per affidavit submitted by Eating house management (placed at C- 39) that the restaurant running at ground floor only in a building comprised of basement, ground plus three upper floors, basement is used only for storage purpose, 1st, 2nd & 3rd floor is permanent closed. Area as per application is 163.87 Sqm. And number of seats- 163.87/1.8 = 91 seats approx.

Keeping in view the compliance of the minimum standards on fire prevention and fire safety required under the rules **it is recommended to grant Fire Safety Certificate** under Rule 35 of the Delhi Fire Service Rule 2010.

Signature of the Inspecting Officer
Name: - R.K. Yadav
Designation: - ADO (DWK)

D.O (Sw)

28/9/26

DCFO (WZ) - Out of stn (Conference)

CFO (HQ)

29/9/26
A.K. MALIK

Dr. Dir.

CFO to Director

6/10/26

CFO (FCOS)

7/10/26
A.K. MALIK

Dy. CFO (WZ)

09/10/2026

ADO (DWK)

PTO