GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

Application ID. 52026100105710 **Dated: 23-11-2026**

SHORTCOMING(S)

With reference to your application ID **52026100105710** dated **23-11-2026** on the subject cited above, it is informed that officer concerned of this department inspected the **Govt. Sarvodaya Kanaya Vidyalaya, New Building** at **Peera Garhi Village, Delhi-87** from fire safety point of view in presence of **Mrs. Rachna Vikas Rathi, Principal** on dated **04/11/2026** During the course of inspection following observations were made:-

1. only one staircase of width of 1.5m is provided against requirement of 02 nos. staircase of 1.5m each

In view of the above, the building can not be considered for issuance of Fire Safety Certificate at this stage. Therefore, the application is rejected with the directions to apply again after compliance of above mentioned shortcomings under intimation to this office for further course of action.

A.K.Malik
Chief Fire Officer

Copy to:-

1. RACHNA TOKAS RATHI , SKV PEERAGARHI VILLAGE , National Market Road, Peeeragarhi Village , Delhi, 110087
2. The Concerned Local/Statutory Authority –

This letter is computer generated and does not require signature.