d82

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

आज़ादी का अमृत महोत्सव

No. F6/DFS/MS/EH/NDZ/2026/ 352

Dated: -22/04/2026

To,

The Chairman,
NDMC, Palika Kendra,
Parliament Street,
New Delhi - 110001

Sub: Regarding renewal of FSC in r/o M/s Gulati Restaurant, Ground Floor, Shop No. 3,4,5,6, Pandara Road Market, New Delhi - 110003.

Sir,

Please refer to online application No. 2026032003202 dated 23/03/2026, on the subject cited above. In this connection, it is to inform you that the said restaurant was inspected by the officers concerned of this department on **07/04/2026** in the presence of **Sh. Ankush, Manager** and following shortcomings were observed: -

1. Manually Operated Electronic Fire Alarm (MOEFA) provided but found non-functional.
2. Detectors found removed in the building.
3. Automatic operation of Fire Pump found removed.

Keeping in view of the above **shortcomings**, the application for renewal of Fire Safety Certificate cannot be considered at this stage and stands **rejected**. Further, the occupancy of the building premises in the absence of requisite fire safety measures shall be at the risk and liability of the owner/occupier.

Yours faithfully,

21/4/26

(Dr. S. K. Tomar)
Chief Fire Officer
Delhi Fire Service

Copy to: -

1. The Commissioner, Municipal Corporation of Delhi, Civic Centre, Minto Road, New Delhi – 110001.
2. The Manager, M/s Gulati Restaurant, Ground Floor, Shop No. 3,4,5,6, Pandara Road Market, New Delhi - 110003.