GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No.F.6/DFS/MS/Hospital/2026/NDZ/357 Dated: 11/08/2026

To,

The Director General of Health Service,
3rd floor Delhi Government Dispensary Building
S-1," School Block, Shakarpur,
Delhi-110092

Subject: -Regarding issuance of Fire Safety inspection in r/o Gupta Multispecialty Hospital located at B-20 Vivek Vihar, Delhi-110095.

Sir,

With reference to your letter No. nil dated 05/05/2026 outdoor diary no 1069 dated 08/05/2026 on the subject cited above. In this connection, it is to inform you that the premises was visited by the officer concerned of this department on dated 25/07/2026 in the presence of Sh. A.K. Gupta, Proprietor, the hospital building comprised of basement, stilt, ground plus three upper floors. During the course of inspection following observations were made:-

1. Alternate staircase is not provided in the basement
2. Door of 02 meter width is not provided at staircase at each floor.
3. Fire Check door not provided in the basement.
4. Smoke management system in the upper floor and basement is not provided
5. An overhead water tank having capacity 5,000 litters are provided against requirement of 10,000 litters.

In view of above, the application for issuance of Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangement s shall be at the risk and liability of the owner/occupier, The Licensing Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully

10/8/26

(Dr. S. K. TOMAR)
CHIEF FIRE OFFICER
DELHI FIRE OFFCIER

Copy to: -

Dr. A. K. Gupta, **M/s** Gupta Multispecialty Hospital at B-20 Vivek Vihar, Delhi-110095