GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUATERS: DELHI FIRE SERVICE: NEW DELHI–110001

No. F.6/DFS/MS/School/CZ/2026/ 142 Dated: 08/09 /2026

FIRE SAFETY CERTIFICATE

Certified that Guru Ram Dass Public Middle School (ID- 1515126), at Tagore Garden, New Delhi-110027, comprised of Ground plus 02 Upper floors owned/occupied by Gurudwara Management Committee have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of Delhi Fire Service in the presence of Mr. Satpal Singh (Manager, Gurudwara Management Committee) and the building/premises is fit for occupancy class **"Group–B Educational (Sub-Division B-1)"** with effect from 08/09/2026 for a period of **three years** in accordance with rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 08/09/2026 at New Delhi by.

8/9/26

(Dr. S.K. Tomar)
Chief Fire Officer
Delhi Fire Service

Copy to: -

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054
2. The Manager, Guru Ram Dass Public Middle School (ID- 1515126), Tagore Garden, New Delhi-110027.

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all times as seen during inspection.
3. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of fire-fighting system.
5. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.
8. An Affidavit no. IN-DL79512939204535Y regarding school running in the premises since 1993 and construction of additional staircase (iron) and maximum no. of students in per classroom.

INSPECTION REPORT				
1	Name & Address of the Building	Guru Ram Dass Public Middle School (ID-1515126), Tagore Garden, New Delhi-110027.		
2	Type of Occupancy	Group- B Educational (Sub- Division B-1)		
3	Building comprised of	Ground + 2 Upper Floor		
4	Type of Case	New case		
5	Details of Previous NOC	Nil		
6	Fire Safety Directives Letter No	F.16/Estate/CC/FireSafety/2011/3298-3398 dated 01.03.2011		
7	Date of Inspection	12/08/2026		
8	Name of the Inspecting Officers	Vinay Kumar (ADO/Patel Nagar)		
9	Name & Designation of Officers from the building side	Mr. Satpal Singh		
10	Year of construction	Before 1993 as per letter of Dy. Director of Education (West)		
11	Applicant letter No.	Outdoor diary no. 3983 dated 20/07/2026		
S. No.	**Minimum standards on Fire Prevention and Fire Safety U/R 33**	**Requirement as per Circular of DOE dated 01.03.2011**	**Provided at Site**	**Remarks**
1	**Access to Building.**			
	• Road width	06m	Provided	MR
	• Gate width	4.5 mtrs	Provided	MR
	• Width of internal road	NA	NA	NA
2	**Number, width, type & arrangement of exits**			
	a. Number of Staircase			
	• Upper floors	02 nos.	Provided 3 nos.	MR
	• Basement floor	NA	NA	NA
	b. Width of Staircase			
	• Upper floors	1.5 m & less (school is running since 1993)	1.5 m, 1.40 m & 1.35 m	MR
	• Basement floor	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircase to terrace	02 nos.	02 nos.	MR
	e. Width of corridor	1.8 m	Provided	MR
	f. Door size	1 m	Provided	MR
3	**Compartmentation.**			
	• Fire check door.	NA	NA	NA
	• Sealing of electrical shafts.	NA	NA	NA
	• Fire rating of shaft door.	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers.	N/A	N/A	N/A
4	**Smoke Management system.**			
	• Basement	NA	NA	NA
	• Upper floors	NA	Natural Ventilation	NA
5	**Fire Extinguishers.**			
	• Total numbers	Required	6 nos.	MR
	• Types	ABC/CO2	ABC/CO2	MR
	• ISI Marking	ISI marked	Provided	MR
6	**First Aid Hose Reels.**			
	• Total numbers on each floor.	01 no.	Provided	MR
	• Length of hose-reel hose.	30 mtrs.	Provided	MR
	• Nozzle Diameter	5 mm	Provided	MR

7	**Automatic fire detection & alarming system.**			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	NA	NA	NA
	• Hooter's location	NA	NA	NA
8	**MOEFA**	NA	Provided	NA
9	**Public Address System**	NA	N/A	N/A
10	**Automatic Sprinkler System**			
	• Basement & Stilt	NA	NA	NA
	• Upper floors	NA	NA	NA
	• Sprinkler above false ceiling	N/A	N/A	N/A
11	**Internal Hydrants.**			
	• Size of Riser/Down-comer	NA	Provided	NA
	• Number of Hydrant per floor	NA	Provided	NA
	• Hose box.	NA	Provided	NA
12	**Yard Hydrants.**			
	• Total number of hydrants.	N/A	N/A	N/A
	• Hose box.	N/A	N/A	N/A
13	**Pumping arrangements.**			
	• **Ground Level**			
	➢ Discharge of main pump.	N/A	N/A	N/A
	➢ Head of main pump.	N/A	N/A	N/A
	➢ Number of main pumps.	N/A	N/A	N/A
	➢ Jockey Pump output.	N/A	N/A	N/A
	➢ Jockey Pump head.	N/A	N/A	N/A
	➢ Standby Pump output.	N/A	N/A	N/A
	➢ Standby Pump head.	N/A	N/A	N/A
	➢ Auto Starting / Manual Stopping.	N/A	N/A	N/A
	➢ Pump House Access	N/A	N/A	N/A
	• **Terrace Level**			
	➢ Discharge of pump.	450 LPM	Provided	MR
	➢ Head of pump.	40 Mtrs.	Provided	MR
	➢ Power supply.	Required	Provided	MR
	➢ Auto starting of pump.	Required	Provided	MR
14	**Captive water storage for Fire Fighting.**			
	• Underground tank capacity.	N/A	N/A	N/A
	➢ Draw-off connection.	N/A	N/A	N/A
	➢ Fire Service Inlet.	N/A	N/A	N/A
	➢ Access to tank.	N/A	N/A	N/A
	• Overhead tank capacity.	10,000 Ltrs.	Provided	MR
15	**Exit Signage.**	Required	Provided	MR
16	**Provision of Lifts.**			
	• Pressurization of lift shaft.	N/A	N/A	N/A
	• Pressurization of lift lobby.	N/A	N/A	N/A
	• Communication in lift car.	N/A	N/A	N/A
	• Fireman's switch.	N/A	N/A	N/A
	• Lift signage.	N/A	N/A	N/A
17	**Standby Power Supply**	Required	Provided	MR
18	**Refuse Area**			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A

N/A

19	**Fire Control Room.**			
	• Detector System Panel.	N/A	N/A	N/A
	• Flow Switch Panel.	N/A	N/A	N/A
	• PA system Panel.	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building floor plan	N/A	N/A	N/A
20	**Special Fire Protection System for the Protection of special Risk, if any:**	N/A	N/A	N/A

Note: The applicant submitted an affidavit regarding school is running since 1993 attached at and letter from Dy. Director of Education (West) is attached at C/7.

The fire protection systems provided in the building were randomly checked, tested and found functional at the time of inspection and shortcoming issued earlier vide letter no. F6/DFS/MS/School/WZ/2026/354 dated 22.04.2026 is rectify by the school management.

Keeping in view of the substantially satisfactory compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, **it is recommended to grant Fire Safety Certificate** under Rule 35 of the Delhi Fire Service Rules, 2010.

Accordingly, DFA is put up for approval and signature please.

25.8.26

Signature of the Inspecting Officer
Vinay Kumar
ADO (Patel Nagar)

DO (CD) 25/8/26

CFO (CENTRAL) 27/8/26

Principal Director CFO to issue.

CFO (CENTRAL) 27/8/26

ADO (CENTRAL)

Sir, F.T. letter is put-up for signature please.

8.9.

C.F.O (central) 9/9/26

MS