C-50

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No F6/DFS/MS/EH/SZ/2026/ 520 Dated: 03/06/2026

FIRE SAFETY CERTIFICATE

Certified that the M/s Haldiram Marketing Pvt. Ltd, located at D-92 Ground Floor, 100 Foot Main Road, Chattarpur Enclave Main Phase-02, New Delhi-110074, in the building comprised of Basement, Ground plus 03 Upper Floors. Owned/occupied by Haldiram Marketing Pvt. Ltd, earlier issued Fire Safety Certificate by this department vide letter no F.6/DFS/MS/EH/2023/SZ/288 dated-21/09/2023. The premises was re-inspected by the officer concerned of this department on 18/05/2026 in the presence Sh. Tarun Kumar (Manager) and found that the said premise have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules,2010 and that the premise is fit for occupancy class "Residential" "Group-D" Assembly building, (Restaurant at Ground floor only) with effect from 03/06/2026 for the period of three years, in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.Conditions mentioned below.

Issued on 03/06/2026 at New Delhi by.

(A.K. Malik)
Chief Fire Officer

Copy to:

1. The Commissioner MCD, Civic Centre, Minto Road, New Delhi- 110002.- to ensure the occupancy as detailed above & deviation if any.
2. The authorized signatory M/s Haldiram Marketing Pvt. Ltd, located at D-92 Ground Floor, 100 Foot Main Road, Chattarpur Enclave Main Phase-02, New Delhi-110074.(Online Portal ID No. 2026050606440 dated-08/05/2026)

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to nonfunctional fire safety measure shall be at the responsibility of the management/occupier.
3. The trained firefighting staff should be available round the clock.
4. Any deviation with regard to the construction etc. shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

INSPECTION REPORT

1. Name & address of the building	M/s Haldiram Marketing Pvt. Ltd, located at D-92 Ground Floor, 100 Foot Main Road, Chattarpur Enclave Main Phase-02, New Delhi-110074.
2. Type of Occupancy	Assembly Building, Group-D, Basement, Ground plus 03 Upper Floors. (Eating House is running at Ground floor only)
3. Type of Case	Renewal
4. Details of Previous NOC	F.6/DFS/MS/EH/2023/SZ/288 dated-21/09/2023
5. Fire Safety directives letter No	Nil
6. Date of inspection	18/05/2026
7. Name of Inspecting Officer	Sh. Sarabjeet Singh ADO (BCP)
8. Name and designation of officers From the building side	Sh. Tarun Kumar (Manager)
9. Year of Construction	1992 (as per online application)
10. Applicant's letter No.	Online-ID No –2026050606440 dated-08/05/2026

S. No	Minimum Standards on fire prevention and fire safety U/R 33	BBL/NBC	Provided at site	Remarks MR/NMR
1.	**Access to building**			
	• Road width	09m	Provided	MR
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2.	**Number, Width, Type & Arrangement of Exits**			
	a. Number of staircases			
	• Upper Floors	NA	NA	NA
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floor	NA	NA	NA
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	NA
	f. Door Size	1.50m each	1.50m & 1.50m	MR
3.	**Compartmentation**			
	a) Fire check door	NA	NA	NA
	b) Sealing of electrical shafts	NA	NA	NA
	c) Fire Rating of shaft door	NA	NA	NA
	d) Water Curtain	NA	NA	NA
	e) Fire Dampers	NA	NA	NA
4.	**Smoke Management System**			
	a) Basements	NA	NA	NA
	b) Upper floors	Required	Provided	MR
5.	**Fire Extinguishers**			
	a) Total numbers	06 nos.	06 nos.	MR
	b) Types	ABC/CO_2	ABC-04/CO_2-02	MR
	c) IS marking	ISI marked	Provided	MR
6.	**First-Aid Hose Reels**			
	a) Total numbers on each floor	01 nos.	Provided	MR
	b) Length of hose reel hose	30m	Provided	MR
	c) Nozzle diameter	5mm	Provided	MR

7.	**Automatic fire detection and alarming system**			
	a) Type of detectors	NA	NA	NA
	b) Location of Main Panel	NA	NA	NA
	c) Location of Repeater Panel	NA	NA	NA
	d) Alternate source of power	NA	NA	NA
	e) Hooters' Location	NA	NA	NA
8.	**MOEFA**	Required	Provided	MR
9.	**Public Address System**	NA	NA	NA
10.	**Automatic Sprinkler System**			
	a) Basement	NA	NA	NA
	b) Ground & Upper Floors	NA	NA	NA
	c) Sprinkler above false ceiling	NA	NA	NA
11.	**Internal Hydrants**			
	a) Size of riser/down-comer	100mm	Provided	MR
	b) Number of hydrants per floor	01 nos.	Provided	MR
	c) Hose Box	01 nos.	Provided	MR
12.	**Yard Hydrants**			
	a) Total number of hydrants	NA	NA	NA
	b) Hose Box	NA	NA	NA
13.	**Pumping Arrangements**			
	• Ground Level			
	➢ Discharge of main Pump	NA	NA	NA
	➢ Head of Main pump	NA	NA	NA
	➢ Number of main pumps	NA	NA	NA
	➢ Jockey Pump out put	NA	NA	NA
	➢ Jockey pump head	NA	NA	NA
	➢ Standby Pump out put	NA	NA	NA
	➢ Standby Pump Head	NA	NA	NA
	➢ Auto Starting/Manual Stopping	NA	NA	NA
	➢ Pump House Access	NA	NA	NA
	Terrace level			
	➢ Discharge of pump	900 LPM	Provided	MR
	➢ Head of the pump	40m	Provided	MR
	➢ Power Supply	Required	Provided	MR
	➢ Auto Starting of pump	Required	Provided	MR
14.	**Captive Water Storage for firefighting**			
	• Underground tank capacity	NA	NA	NA
	➢ Draw-off connection	NA	NA	NA
	➢ Fire service inlet	NA	NA	NA
	➢ Access to tank	NA	NA	NA
	• Overhead Tank capacity	20,000 ltrs.	Provided	MR
15.	**Exit Signage.**	Required	Provided	MR
16.	**Provision of Lifts.**			
	a) Pressurization of Lift Shaft	NA	NA	NA
	b) Pressurization of Lift lobby	NA	NA	NA
	c) Communication In lift Car	NA	NA	NA
	d) Fireman's Grounding Switch	NA	NA	NA
	e) Lift Signage	NA	NA	NA
17.	**Standby power supply**	NA	NA	NA

N/8

18.	**Refuge Area.**			
	a) Total Area	NA	NA	NA
	b) Location	NA	NA	NA
19.	**Fire Control Room**			
	a) Detector System Panel	NA	NA	NA
	b) Flow Switch Panel	NA	NA	NA
	c) PA System Panel	NA	NA	NA
	d) Battery backup	NA	NA	NA
	e) Building Floor Plans	NA	NA	NA
20.	**Special Fire Protection System for Protection of special Risks, if any:**	NA	NA	NA

The fire protection systems provided in the building were checked randomly and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F.6/DFS/MS/EH/2023/SZ/288 dated-21/09/2023, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended. Accordingly, DFA is put up for approval and signatures please.

Last Date of Disposal -05/06/2026.

SDO 21/05/26

Name - Sarabjeet Singh
Designation –ADO (BCP)

DO (SD) Please clarify the composition of building. Previously G+2, now the building is G+3.

21/5/26
Ravinder Singh

ADO/BCP Sir, in previous inspection, building composition was B+G+2 U. Floor. but at present it is B+G+3 U. Floors and applicant has submitted the drawing of bld. in same as it was in previous inspection. Hence, it seems that it was a typical mistake by the then officer. Actually, bld is B+G+3 U. Floors.

Submitted plz.

SDO 23/05/26
Sarabjeet Singh

SDO 25/5/26

CFO 25/5/26

Ravinder Singh

28/5/26
A.K. MALIK
Principal Director

29/5/26
A.K. MALIK
CFO

29/5/26