C198

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No F.6/DFS/MS/EH/SZ/2026/ 362

Dated: 23/04/2026

To,

The Commissioner MCD,
Civic Centre, Minto Road,
New Delhi- 110002.

Sub: Regarding renewal of Haldiram Restaurant (A Unit of Haldiram Marketing Pvt. Ltd). located at Plot No R-11, Block-R -11, Green Park Main, New Delhi-110016.

Sir,

Please refer to your online application no. No. 2026032303382 dated- 23/03/2026, on the subject cited above. In this connection, it is to inform you that the premises was inspected by officer concerned of this department on 09/04/2026 in the presence of Sh. Ganesh Kumar (Manager) to see the functioning of fire safety Equipments provided in the building.

During inspection, it has been observed that the said eating house/restaurant is running at ground, first & second floor), building is comprised of Ground + 02 Upper Floors, was issued FSC vide letter no. F.6/DFS/MS/EH/2023/SZ/272 dated-31/08/2023. Fire safety arrangements such as Fire Extinguishers, MOEFA etc. provided. However, the following shortcomings were observed.

1. Smoke management system is provided but not functional.
2. MOEFA is provided but not functional.
3. Main fire pump capacity of 2 X 450 LPM, are provided but not on auto-mode.

In view of above Shortcomings, the application for renewal of Fire safety Certificate is cannot considered at this stage & rejected. The occupancy of the building/premises in absence of requisites fire safety arrangements shall be at the risk and liabilities of the Owner/occupier.

Yours faithfully,

23/4/26

(A.K. Malik)
Chief Fire Officer

Copy To: -

1. The Owner/occupier M/s. Haldiram Restaurant (A Unit of Haldiram marketing Pvt. Ltd). located at Plot No R-11, Block-R -11, Green Park Main, New Delhi-110016 (Online application No. 2026032303382 dated- 23/03/2026)