GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

आज़ादी का अमृत महोत्सव

No. F6/DFS/MS/EH/SZ/2026/ 555 Dated: 16/06/2026

FIRE SAFETY CERTIFICATE

Certified that the M/s Haldiram Restaurant (Haldiram Marketing Private Limited) located at 45, Ring Road, Lajpat Nagar - III, New Delhi – 110024 was running at ground floor of the building which is comprised of basement, ground plus two upper floors as earlier Fire Safety Certificate issued from this department vide letter No. F6/DFS/MS/EH/SZ/2023/182 dated 12/06/2023. The said premises was re-inspected by the officer concerned of this department on 05/06/2026 in presence of Mr. Mr. Chandan (Area Manager) and found that the fire premises / building have deemed complied with the prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule 2010 and that the premises / building is fit for occupancy class Group D "**Assembly Building**" (Restaurant running on ground floor only) with effect from 16 /06 /2026 valid upto 31.03.2029 in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rule 2010, printed below.

Issued 16/06/2026 **at New Delhi by.**

15/6/26

(A. K. Malik)
Chief Fire Officer

O/C 12/6/26

Copy to: -

1. The DHO, (South Zone), MCD, Public Health Department, Aurobindo Marg, Green Park, New Delhi – 110016. (Ref. MCD portal ID - 2026052707562 dated 27/05/2026).
2. The Manager, Haldiram Restaurant (Haldiram Marketing Private Limited) located at 45, Ring Road, Lajpat Nagar - III, New Delhi – 110024.

Conditions for the validity of fire safety certificate

1. This FSC is valid for Ground Floor Only.
2. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
3. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. The trained firefighting staff should be available round the clock.
5. Any deviation w. r. t. construction etc. shall be verified by the concerned building sanctioning authority.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
8. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
9. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six months prior to its expiry".

INSPECTION REPORT

1	Name & Address of the building	M/s Haldiram Restaurant (Haldiram Marketing Private Limited) located at 45, Ring Road, Lajpat Nagar - III, New Delhi – 110024.
2	Building is comprised of	Basement + Ground + 02 Upper Floors. Basement and upper floors used as a store. Restaurant running at ground floor only.
3	Type of occupancy	Assembly Building (Group – D)
4	Type of case	Renewal
5	Details of previous FSC	F6/DFS/MS/EH/SZ/2023/182 dated 12/06/2023
6	Fire safety direction letter no.	NBC/UBBL
7	Date of inspection	05/06/2026
8	Name of the inspecting officers	Yashwant Singh Meena, ADO/M. Road
9	Name of the designation of officer From the building side	Mr. Chandan (Area Manager)
10	Year of construction	1999
11	Applicant's letter no.	MCD Application No. 2026052707562 dated 27/05/2026

S. No	Minimum standard of Fire Prevention and Fire Safety U/R 33		Requirements as per Rule 35(6)	Provide at site	Remarks MR/NMR
1	**Access to Building**				
	A	Road width	6.0 metres.	Provided	MR
	B	Gate width	-NA-	-NA-	-NA-
	C	Width of internal roads	-NA-	-NA-	-NA-
2	**Number, Width, Type & Arrangement of Exits**				
	A	No. of staircase:	**Restaurant at ground floor only**		
		a) Upper floor	-NA-	-NA-	-NA-
		b) Basements	-NA-	-NA-	-NA-
	B	Width of the staircase:			
		a) Upper floors	-NA-	-NA-	-NA-
		b) Basements	-NA-	-NA-	-NA-
	C	Protection of Exits			
		a) Fire check door	Required	Provided	MR
		b) Pressurization	-NA-	-NA-	-NA-
	D	No. of continuous staircase to terrace:	-NA-	-NA-	-NA-
	E	Width of the corridor	-NA-	-NA-	-NA-
	F	Door size	1.50 metres & 1.0 meters.	1.50 metres & 1.0 meters.	MR
3	**Compartmentation:**				
	A	Fire check doors	NA-	NA-	NA-
	B	Sealing of horizontal & vertical opening	-NA-	-NA-	-NA-
	C	Fire rating of shaft doors	-NA-	-NA-	-NA-
	D	Water curtain	-NA-	-NA-	-NA-
	E	Fire dampers	-NA-	-NA-	-NA-
4	**Smoke management System:**				
	A	Basements	Mechanical/Natural	Exhaust Fan	MR
	B	Upper floors	Mechanical/Natural	Natural	MR
5	**Fire Extinguishers**				
	A	Total numbers	14 nos.	15 nos.	MR
	B	Types	ABC & CO2	ABC & CO2	MR
	C	ISI marking	ISI Marking	Provided	MR

6	**First Aid Hose Reel**				
	A	Total no. at each floor	01 no.	01 no.	MR
	B	Length of hose reel	30 m	30 m	MR
	C	Nozzle diameter	05 mm	05 mm	MR
7	**Automatic Fire Detection and Alarm System**				
	A	Type of detectors	-NA-	Smoke & Heat	-NA-
	B	Location of main Panel	-NA-	Ground floor	-NA-
	C	Location of repeater panel	-NA-	N/A	-NA-
	D	Alternate power source	-NA-	N/A	-NA-
	E	Hooter's location	-NA-	Audible in entire building.	-NA-
8	MOEFA		Required	Provided	MR
9	Public Address System		-NA-	-NA-	-NA-
10	**Automatic Sprinkler System**				
	A	Basement	Required	Provided	MR
	B	Upper floor	-NA-	-NA-	-NA-
	C	Sprinklers above false ceiling	-NA-	-NA-	-NA-
11	**Internal Hydrants**				
	A	Size of the riser/down comer	100 mm	100 mm	MR
	B	No. of hydrants per floor	01 no.	01 no.	MR
	C	Hose box	01 no.	01 no.	MR
12	**Yard Hydrants**				
	A	Total no. of hydrants	-NA-	-NA-	-NA-
	B	Hose box	-NA-	-NA-	-NA-
13	**Pumping arrangements**				
	A	Ground Level			
		a) Discharge of main pump	-NA-	-NA-	-NA-
		b) Head of Main Pump	-NA-	-NA-	-NA-
		c) Number of Main Pump	-NA-	-NA-	-NA-
		d) Jockey Pump out put	-NA-	-NA-	-NA-
		e) Jockey Pump Head	-NA-	-NA-	-NA-
		f) Standby Pump out put	-NA-	-NA-	-NA-
		g) Standby Pump Head	-NA-	-NA-	-NA-
		h) Auto Starting/ Manual stopping	-NA-	-NA-	-NA-
	B	Terrace Level			
		Discharge of Pump	450 LPM	Provided	MR
		Head of terrace pump	40 metres	40 metres	MR
		Power supply	Required	Provided	MR
		Auto starting of pump	Required	Provided	MR
14	**Captive Water Storage for Fire Fighting.**				
	A	Underground tank capacity	-NA-	20,000 litres	-NA-
	B	Draw off connection	-NA-	-NA-	-NA-
	C	Fire Service Inlet	-NA-	-NA-	-NA-
	E	Access to tank	-NA-	-NA-	-NA-
	D	Overhead tank capacity	10,000 litres	Provided	MR
15	**Exit Signage**		Required	Provided	MR
16	**Provision of lift**				
	A	Pressurization of lift shaft	-NA-	-NA-	-NA-
	B	Pressurization of lift lobby	-NA-	-NA-	-NA-
	C	Communication in lift car	-NA-	-NA-	-NA-
	D	Fireman switch	-NA-	-NA-	-NA-
	E	Lift signage	-NA-	-NA-	-NA-
17	**Standby Power Supply**		Required	Provided	MR

Haldiram Restaurant (Haldiram Marketing Private Limited) located at 45, Ring Road, Lajpat Nagar - III, New Delhi – 110024

18	**Refuge Area**				
	A	location	-NA-	-NA-	-NA-
	B	Total area	-NA-	-NA-	-NA-
19	**Fire Control Room**				
	A	Fire Detection System panel	-NA-	-NA-	-NA-
	B	Flow switch panel	-NA-	-NA-	-NA-
	C	P A system panel	-NA-	-NA-	-NA-
	D	Battery backup	-NA-	-NA-	-NA-
	E	Building floor plan	-NA-	-NA-	-NA-
20	**Special Fire Protection for special risk if any**				
	A	Special Fire Protection system for Protection of Special Risk, if any:	-NA-	-NA-	-NA-

The fire protection systems provided in the building were tested, checked at random and foun functional at the time of inspections.

Keeping in view of the substantial compliance of the minimum standards on fire prevention an fire safety measures as required under the rules, the FSC issued vide letter N F6/DFS/MS/EH/SZ/2023/182 dated 12/06/2023 renewal under the Rules 37 of Delhi Fire Servic Rules 2010 is **recommended**.

te: - Last disposal date of the case is 25.06.2026

8/6/2026

Signature of the Inspecting Officer
Name: Yashwant Singh Meena
Designation: ADO/Mathura Road

D.O/SD

8/6/26
Ravinder Singh

CFO(SZ)

9/6/26
A.K. MALIK
Principal Director

CFO to Issue.
09/06/26

CFO(SZ)

11/6/26
A.K. MALIK
Principal Director

DO(SD)

12/6/26
Ravinder Singh
ADO/SD