C-46

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

NO.F.6/DFS/MS/FH/2026/ 231

Dated: 19/03/2026

To,

The Commissioner,
Municipal Corporation of Delhi,
Dr. SPM Civic Center, Minto Road,
New Delhi–110002.

Sub: - Reply of application regarding FSC/NOC in r/o **Haldi Foods located at 14/48, Ground & Mezzanine Floor, Shopping Centre, Malcha Marg, New Delhi - 110021.**

Sir,

This has a reference to online ID- 2026022802231 dated 28/02/2026 on the subject cited above. In this connection, it is to inform you that the premise was visited by the officer concerned of this department on 07/03/2026 in the presence of Sh. Deshraj, Manager. During course of inspection, the shortcomings observed are as below: -

1. Hose reel found non- functional.
2. MOEFA found non-functional.
3. Automatic sprinkler system found non-functional.
4. Terrace pump found non-functional.
5. Auto starting of terrace pump found non-functional.

In view of the above, application for fire safety certificate is rejected. You are requested to rectify the above shortcomings under intimation to this department for further action in the matter. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of owner/occupier of the establishment. The Licensing Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

19/3/26

(A. K. Malik)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to: -

1. Sh. Deshraj, Manager, M/s Haldi Foods located at 14/48, Ground & Mezzanine Floor, Shopping Centre, Malcha Marg, New Delhi - 110021.