GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

आज़ादी का अमृत महोत्सव

E34

No. F6 /DFS/MS/School/SW/2026/829 Dated:07/09 /2026

To,

The Authorized Signatory,
Harsh Public School
E – 19, Jai Vihar,
Najafgarh, New Delhi – 110043.

Subject: - Regarding grant of Fire Safety Certificate in r/o Harsh Public School located at E – 19, Jai Vihar, Najafgarh, New Delhi – 110043.

Sir,

This has a reference to your letter received vide Outdoor dairy No. 4366 dated 27/07/2026, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 12/06/2026 in the presence of Mrs. Banita (Principal) & Mr. Rajesh Kumar (Manager) and observed that building comprised of Ground plus one upper floor and one room on terrace, following shortcomings were observed during the inspection:

1. The building is not approachable through 6.0 meters wide road.
2. First Aid Hose Reel provided but found nonfunctional.
3. Terrace Level Pump is of 450 LPM provided but found nonfunctional.
4. Overhead water storage tank capacity 10,000 liters found empty.
5. Exit & floors Signage's not provided at strategic location in the building.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

3/9/26

(A. K.Malik)
Chief Fire Officer
Delhi Fire Service
o/c

Copy to: -

1. The Director of Education, (GNCT), Old Secretariat, Civil Line, Delhi - 110054.