C/133

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No. F6/DFS/MS/2025/School/ 874 Dated: 08/12/2025

To

The Principal
Holy Father Model School
Gole Market, Pratap Vihar, New Delhi-86.

Sub: Regarding issuance of fire safety certificate in r/o Holy Father Model School at Gole Market, Pratap Vihar, New Delhi-110086.

Sir,

Please refer to your letter no. Nil dated 04/11/2025 received in this department vide outdoor dairy n o. 7899 dated 06/11/2025 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officer concerned of this department on 14/11/2025 observed that as per earlier Fire Safety Certificate issued by this department vide letter of even no. F6/DFS/MS/2022/School/WZ/832 Dated: 02/08/2022 for ground floor only. Now the school management has running on school ground & first floors. At the time of inspection Sh. Ishaan Thakur was also present at site. During the course of inspection observations/ shortcomings made are as under:-

1. The class rooms door having width of 1.10m against the requirement of 1.20m
2. Hose reel hose is not provided.
3. Terrace level fire pump capacity of 450 LPM is not provided.
4. Terrace level fire water tank capacity of 10,000 Ltr is not provided.
5. Exit & floors signage's is not provided at strategic location in the school building.
6. Standby power supply is not provided.

Keeping in view of above, grant of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of school premises is at your own risk & responsibility.

Yours faithfully

08/12/25

S.K. Dua
Dy. Chief Fire Officer
Delhi Fire Service

Copy to:-

1. The Dy. Director of Education, Zone- XIII, District North West- B (II), Sector-9, Rohini, Delhi – 110085.