GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No.F6/DFS/MS/ School/WZ /2025/ 745 Dated 23/09/2025

To,

The Principal,
Holy Father Model School,
Pratap Vihar, Gole Market, Kirari Ext.
Delhi-110086.

Sub:- Issuance of Fire Safety Certificate in r/o Holy Father Model School, Pratap Vihar, Gole Market, Kirari Ext. Delhi-86.

Sir,

Kindly refer to letter received in this department through outdoor diary no. 4092 dated 24.07.2025 on the subject cited above. In this connection, it is to inform you that the shortcoming already issued by this department letter of even No. 324 dated 02.05.2025 (Copy enclosed). Therefore, you are advised to submit point-wise compliance of shortcomings issued vide this department letter dated 02.05.2025 for further consideration in this matter.

Yours Faithfully

19/09/2025

(Virendra Singh)
Chief Fire Officer
Delhi Fire Service

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No.F6/DFS/MS/ School/WZ /2025/ 324 Dated 02/05/2025

To,

The Principal,
Holy Father Model School,
Pratap Vihar, Gole Market, Kirari Ext.
Delhi-110086.

Sub:- Issuance of Fire Safety Certificate in r/o Holy Father Model School, Pratap Vihar, Gole Market, Kirari Ext. Delhi-86.

Sir,

Kindly refer to online mail dated 03.03.2025, received in this department on the subject cited above. In this connection this is to inform you that the inspection of the above said premises was carried out by the officer concerned of this department on **22.04.2025** and observed that addition of one more floor found on existing building of ground floor, making it ground + one upper floors & no fire protection system is provided. Therefore you are requested to provide fire protection system as per NBC Part-IV/ Directorate & education circular-2011 and also provided approved/ as built plans for further consideration in this matter.

Yours faithfully

(Atul Garg)
DIRECTOR
Ph; 011-23414000